

Maximum Floor Spans

General Notes

1. The tabulated spans may differ slightly from software programs.
2. It is preferable to use a software to reflect true conditions (span(s), loads, floor assembly, etc.). Alternatively, other tables are available on demand.

Index

Number	Live load (psf)	Dead load (psf)	Spans	Deflection limit	Floor system	Sheathing	
						Thickness (in.)	Type
S1.1	40	15	Simple	L/480	Glued-nailed	19/32	OSB
S1.2	40	15	Multiple	L/480	Glued-nailed	19/32	OSB
S2.1	40	15	Simple	L/480	Glued-nailed	5/8	OSB
S2.2	40	15	Multiple	L/480	Glued-nailed	5/8	OSB
S3.1	40	15	Simple	L/480	Glued-nailed	23/32	OSB
S3.2	40	15	Multiple	L/480	Glued-nailed	23/32	OSB
S4.1	40	15	Simple	L/480	Glued-nailed	3/4	OSB
S4.2	40	15	Multiple	L/480	Glued-nailed	3/4	OSB
S5.1	40	15	Simple	L/480	Glued-nailed	7/8	OSB
S5.2	40	15	Multiple	L/480	Glued-nailed	7/8	OSB
S6.1	40	15	Simple	L/480	Glued-nailed	5/8	Plywood
S6.2	40	15	Multiple	L/480	Glued-nailed	5/8	Plywood
S7.1	40	15	Simple	L/480	Glued-nailed	3/4	Plywood
S7.2	40	15	Multiple	L/480	Glued-nailed	3/4	Plywood
M1.1	40	20	Simple	L/480	Glued-nailed	19/32	OSB
M1.2	40	20	Multiple	L/480	Glued-nailed	19/32	OSB
M2.1	40	20	Simple	L/480	Glued-nailed	5/8	OSB
M2.2	40	20	Multiple	L/480	Glued-nailed	5/8	OSB
M3.1	40	20	Simple	L/480	Glued-nailed	23/32	OSB
M3.2	40	20	Multiple	L/480	Glued-nailed	23/32	OSB
M4.1	40	20	Simple	L/480	Glued-nailed	3/4	OSB
M4.2	40	20	Multiple	L/480	Glued-nailed	3/4	OSB
M5.1	40	20	Simple	L/480	Glued-nailed	7/8	OSB
M5.2	40	20	Multiple	L/480	Glued-nailed	7/8	OSB
M6.1	40	20	Simple	L/480	Glued-nailed	5/8	Plywood
M6.2	40	20	Multiple	L/480	Glued-nailed	5/8	Plywood
M7.1	40	20	Simple	L/480	Glued-nailed	3/4	Plywood
M7.2	40	20	Multiple	L/480	Glued-nailed	3/4	Plywood
H1.1	40	35	Simple	L/480	Glued-nailed	19/32	OSB
H1.2	40	35	Multiple	L/480	Glued-nailed	19/32	OSB
H2.1	40	35	Simple	L/480	Glued-nailed	5/8	OSB
H2.2	40	35	Multiple	L/480	Glued-nailed	5/8	OSB
H3.1	40	35	Simple	L/480	Glued-nailed	23/32	OSB
H3.2	40	35	Multiple	L/480	Glued-nailed	23/32	OSB
H4.1	40	35	Simple	L/480	Glued-nailed	3/4	OSB
H4.2	40	35	Multiple	L/480	Glued-nailed	3/4	OSB
H5.1	40	35	Simple	L/480	Glued-nailed	7/8	OSB
H5.2	40	35	Multiple	L/480	Glued-nailed	7/8	OSB
H6.1	40	35	Simple	L/480	Glued-nailed	5/8	Plywood
H6.2	40	35	Multiple	L/480	Glued-nailed	5/8	Plywood
H7.1	40	35	Simple	L/480	Glued-nailed	3/4	Plywood
H7.2	40	35	Multiple	L/480	Glued-nailed	3/4	Plywood

Maximum Floor Spans – S1.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-0"	-
	NI-80	17'-0"	16'-0"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-3"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-5"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-8"	17'-6"	16'-11"	-
	NI-80	19'-5"	17'-11"	17'-4"	-	20'-0"	18'-6"	17'-9"	-
14"	NI-90	19'-10"	18'-4"	17'-7"	-	20'-5"	18'-10"	18'-0"	-
	NI-40x	19'-9"	18'-4"	17'-8"	-	20'-6"	19'-0"	18'-3"	-
	NI-60	20'-1"	18'-7"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-7"	19'-11"	19'-1"	-	22'-3"	20'-7"	19'-8"	-
16"	NI-90	22'-0"	20'-4"	19'-5"	-	22'-8"	21'-0"	20'-0"	-
	NI-60	21'-11"	20'-4"	19'-5"	-	22'-8"	21'-1"	20'-2"	-
	NI-80	23'-6"	21'-9"	20'-9"	-	24'-3"	22'-5"	21'-5"	-
	NI-90	23'-11"	22'-1"	21'-2"	-	24'-8"	22'-10"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-7"	15'-2"	14'-4"	-	16'-7"	15'-2"	14'-4"	-
	NI-40x	17'-9"	16'-10"	16'-1"	-	18'-3"	17'-0"	16'-1"	-
	NI-60	17'-11"	16'-11"	16'-4"	-	18'-5"	17'-3"	16'-4"	-
	NI-80	19'-2"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	18'-0"	17'-2"	-	19'-11"	18'-2"	17'-2"	-
	NI-40x	20'-10"	19'-4"	18'-6"	-	21'-5"	19'-11"	19'-1"	-
	NI-60	21'-1"	19'-7"	18'-9"	-	21'-8"	20'-2"	19'-4"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
14"	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
	NI-40x	23'-5"	21'-9"	20'-9"	-	24'-1"	22'-5"	21'-5"	-
	NI-60	23'-9"	22'-1"	21'-1"	-	24'-5"	22'-9"	21'-9"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
16"	NI-90	25'-10"	23'-11"	22'-10"	-	26'-5"	24'-6"	23'-5"	-
	NI-60	26'-3"	24'-3"	23'-2"	-	26'-11"	25'-1"	23'-11"	-
	NI-80	27'-11"	25'-10"	24'-8"	-	28'-7"	26'-6"	25'-4"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S1.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-8"	-	16'-7"	15'-8"	15'-2"	-
	NI-40x	17'-2"	16'-2"	15'-8"	-	17'-8"	16'-8"	16'-1"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-6"	17'-4"	16'-9"	-	19'-1"	17'-9"	17'-1"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-6"	-	18'-11"	17'-8"	17'-1"	-
	NI-40x	19'-8"	18'-3"	17'-7"	-	20'-4"	18'-11"	18'-2"	-
	NI-60	19'-11"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-4"	-
	NI-80	21'-5"	19'-10"	19'-0"	-	22'-1"	20'-6"	19'-7"	-
14"	NI-90	21'-11"	20'-3"	19'-4"	-	22'-6"	20'-10"	19'-11"	-
	NI-40x	21'-9"	20'-3"	19'-4"	-	22'-7"	21'-0"	20'-2"	-
	NI-60	22'-2"	20'-7"	19'-8"	-	23'-0"	21'-4"	20'-5"	-
	NI-80	23'-10"	22'-0"	21'-1"	-	24'-7"	22'-9"	21'-9"	-
16"	NI-90	24'-4"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-
	NI-60	24'-2"	22'-5"	21'-5"	-	25'-1"	23'-4"	22'-4"	-
	NI-80	26'-0"	24'-0"	22'-11"	-	26'-10"	24'-10"	23'-9"	-
	NI-90	26'-6"	24'-5"	23'-4"	-	27'-4"	25'-3"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	16'-6"	15'-8"	-	18'-1"	16'-6"	15'-8"	-
	NI-40x	19'-4"	18'-0"	17'-3"	-	19'-11"	18'-6"	17'-3"	-
	NI-60	19'-7"	18'-2"	17'-6"	-	20'-2"	18'-9"	17'-9"	-
	NI-80	21'-0"	19'-6"	18'-8"	-	21'-6"	20'-0"	19'-2"	-
11-7/8"	NI-20	21'-1"	19'-7"	18'-7"	-	21'-8"	19'-10"	18'-7"	-
	NI-40x	22'-9"	21'-1"	19'-9"	-	23'-5"	21'-7"	19'-9"	-
	NI-60	23'-0"	21'-4"	20'-5"	-	23'-8"	22'-1"	21'-2"	-
	NI-80	24'-7"	22'-10"	21'-10"	-	25'-3"	23'-5"	22'-5"	-
14"	NI-90	25'-1"	23'-3"	22'-3"	-	25'-9"	23'-10"	22'-10"	-
	NI-40x	25'-6"	23'-8"	21'-8"	-	26'-4"	23'-9"	21'-8"	-
	NI-60	25'-11"	24'-1"	23'-0"	-	26'-8"	24'-10"	23'-9"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
16"	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-7"	-
	NI-60	28'-7"	26'-6"	25'-3"	-	29'-5"	27'-4"	26'-2"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-3"	29'-0"	27'-8"	-
	NI-90	31'-0"	28'-9"	27'-4"	-	31'-9"	29'-6"	28'-2"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S2.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-1"	14'-3"	13'-10"	-	15'-7"	14'-9"	14'-3"	-
	NI-40x	16'-2"	15'-3"	14'-8"	-	16'-7"	15'-8"	15'-1"	-
	NI-60	16'-4"	15'-4"	14'-10"	-	16'-9"	15'-9"	15'-3"	-
	NI-80	17'-3"	16'-3"	15'-8"	-	17'-8"	16'-7"	16'-0"	-
11-7/8"	NI-20	17'-0"	16'-0"	15'-6"	-	17'-6"	16'-7"	16'-0"	-
	NI-40x	18'-2"	17'-1"	16'-6"	-	18'-9"	17'-6"	16'-11"	-
	NI-60	18'-5"	17'-3"	16'-8"	-	19'-0"	17'-8"	17'-1"	-
	NI-80	19'-9"	18'-3"	17'-7"	-	20'-4"	18'-10"	18'-0"	-
14"	NI-90	20'-2"	18'-8"	17'-10"	-	20'-9"	19'-2"	18'-4"	-
	NI-40x	20'-1"	18'-8"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-60	20'-6"	18'-11"	18'-2"	-	21'-2"	19'-8"	18'-9"	-
	NI-80	21'-11"	20'-3"	19'-4"	-	22'-7"	20'-11"	20'-0"	-
16"	NI-90	22'-5"	20'-8"	19'-9"	-	23'-0"	21'-4"	20'-4"	-
	NI-60	22'-4"	20'-8"	19'-9"	-	23'-1"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-9"	-
	NI-90	24'-5"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-3"	14'-5"	-	16'-8"	15'-3"	14'-5"	-
	NI-40x	17'-11"	17'-0"	16'-1"	-	18'-5"	17'-1"	16'-1"	-
	NI-60	18'-2"	17'-1"	16'-4"	-	18'-8"	17'-4"	16'-4"	-
	NI-80	19'-5"	18'-0"	17'-5"	-	19'-10"	18'-5"	17'-8"	-
11-7/8"	NI-20	19'-7"	18'-2"	17'-3"	-	19'-11"	18'-3"	17'-3"	-
	NI-40x	21'-1"	19'-7"	18'-8"	-	21'-8"	20'-2"	19'-2"	-
	NI-60	21'-4"	19'-9"	18'-11"	-	21'-11"	20'-5"	19'-6"	-
	NI-80	22'-9"	21'-1"	20'-2"	-	23'-3"	21'-8"	20'-8"	-
14"	NI-90	23'-3"	21'-6"	20'-6"	-	23'-9"	22'-0"	21'-0"	-
	NI-40x	23'-8"	21'-11"	20'-11"	-	24'-4"	22'-8"	21'-8"	-
	NI-60	24'-0"	22'-3"	21'-3"	-	24'-8"	22'-11"	21'-11"	-
	NI-80	25'-7"	23'-9"	22'-7"	-	26'-2"	24'-4"	23'-3"	-
16"	NI-90	26'-1"	24'-2"	23'-0"	-	26'-8"	24'-9"	23'-7"	-
	NI-60	26'-5"	24'-6"	23'-5"	-	27'-2"	25'-3"	24'-2"	-
	NI-80	28'-2"	26'-1"	24'-10"	-	28'-10"	26'-9"	25'-6"	-
	NI-90	28'-8"	26'-6"	25'-3"	-	29'-3"	27'-2"	25'-11"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S2.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-3"	15'-4"	14'-10"	-	16'-10"	15'-11"	15'-5"	-
	NI-40x	17'-5"	16'-5"	15'-10"	-	17'-11"	16'-11"	16'-4"	-
	NI-60	17'-7"	16'-7"	16'-0"	-	18'-1"	17'-0"	16'-5"	-
	NI-80	18'-10"	17'-6"	16'-11"	-	19'-5"	18'-0"	17'-4"	-
11-7/8"	NI-20	18'-5"	17'-3"	16'-9"	-	19'-3"	17'-11"	17'-4"	-
	NI-40x	20'-0"	18'-7"	17'-9"	-	20'-8"	19'-3"	18'-5"	-
	NI-60	20'-3"	18'-10"	18'-0"	-	21'-0"	19'-6"	18'-8"	-
	NI-80	21'-10"	20'-2"	19'-3"	-	22'-5"	20'-10"	19'-10"	-
14"	NI-90	22'-3"	20'-7"	19'-8"	-	22'-11"	21'-2"	20'-3"	-
	NI-40x	22'-2"	20'-7"	19'-8"	-	23'-0"	21'-4"	20'-6"	-
	NI-60	22'-7"	20'-11"	20'-0"	-	23'-4"	21'-8"	20'-9"	-
	NI-80	24'-3"	22'-5"	21'-5"	-	25'-0"	23'-2"	22'-1"	-
16"	NI-90	24'-9"	22'-10"	21'-10"	-	25'-6"	23'-7"	22'-6"	-
	NI-60	24'-7"	22'-10"	21'-9"	-	25'-6"	23'-8"	22'-8"	-
	NI-80	26'-5"	24'-5"	23'-4"	-	27'-3"	25'-3"	24'-1"	-
NI-90	26'-11"	24'-11"	23'-9"	-	27'-9"	25'-8"	24'-6"	-	

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-1"	16'-7"	15'-8"	-	18'-1"	16'-7"	15'-8"	-
	NI-40x	19'-7"	18'-3"	17'-3"	-	20'-2"	18'-7"	17'-3"	-
	NI-60	19'-10"	18'-5"	17'-8"	-	20'-5"	18'-10"	17'-9"	-
	NI-80	21'-3"	19'-8"	18'-10"	-	21'-9"	20'-3"	19'-4"	-
11-7/8"	NI-20	21'-4"	19'-10"	18'-7"	-	21'-9"	19'-10"	18'-7"	-
	NI-40x	23'-0"	21'-4"	19'-9"	-	23'-8"	21'-7"	19'-9"	-
	NI-60	23'-3"	21'-7"	20'-8"	-	23'-11"	22'-4"	21'-3"	-
	NI-80	24'-11"	23'-1"	22'-0"	-	25'-6"	23'-8"	22'-8"	-
14"	NI-90	25'-5"	23'-6"	22'-5"	-	26'-0"	24'-1"	23'-0"	-
	NI-40x	25'-9"	23'-9"	21'-8"	-	26'-7"	23'-9"	21'-8"	-
	NI-60	26'-2"	24'-4"	23'-2"	-	26'-11"	25'-1"	24'-0"	-
	NI-80	28'-0"	25'-11"	24'-9"	-	28'-8"	26'-8"	25'-5"	-
16"	NI-90	28'-6"	26'-5"	25'-2"	-	29'-2"	27'-1"	25'-10"	-
	NI-60	28'-10"	26'-9"	25'-6"	-	29'-8"	27'-8"	26'-5"	-
	NI-80	30'-9"	28'-6"	27'-2"	-	31'-6"	29'-3"	27'-11"	-
NI-90	31'-4"	29'-0"	27'-8"	-	32'-1"	29'-9"	28'-5"	-	

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S3.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-9"	14'-10"	14'-4"	13'-5"	16'-2"	15'-4"	14'-6"	13'-5"
	NI-40x	16'-10"	15'-10"	15'-3"	14'-8"	17'-2"	16'-3"	15'-8"	15'-0"
	NI-60	16'-11"	16'-0"	15'-5"	14'-9"	17'-4"	16'-4"	15'-9"	15'-2"
	NI-80	18'-0"	16'-11"	16'-3"	15'-7"	18'-5"	17'-3"	16'-7"	15'-11"
11-7/8"	NI-20	17'-8"	16'-8"	16'-1"	15'-6"	18'-3"	17'-3"	16'-7"	16'-0"
	NI-40x	19'-1"	17'-9"	17'-1"	16'-5"	19'-8"	18'-3"	17'-6"	16'-10"
	NI-60	19'-4"	17'-11"	17'-3"	16'-7"	19'-11"	18'-6"	17'-8"	17'-0"
	NI-80	20'-9"	19'-2"	18'-3"	17'-5"	21'-3"	19'-8"	18'-9"	17'-10"
14"	NI-90	21'-2"	19'-7"	18'-8"	17'-9"	21'-8"	20'-1"	19'-1"	18'-1"
	NI-40x	21'-2"	19'-7"	18'-8"	17'-9"	21'-10"	20'-3"	19'-4"	18'-4"
	NI-60	21'-6"	19'-11"	19'-0"	18'-0"	22'-2"	20'-7"	19'-8"	18'-8"
	NI-80	23'-1"	21'-4"	20'-3"	19'-3"	23'-8"	21'-11"	20'-10"	19'-9"
16"	NI-90	23'-6"	21'-9"	20'-8"	19'-7"	24'-1"	22'-4"	21'-3"	20'-1"
	NI-60	23'-5"	21'-8"	20'-8"	19'-7"	24'-2"	22'-5"	21'-5"	20'-4"
	NI-80	25'-1"	23'-2"	22'-1"	20'-11"	25'-9"	23'-10"	22'-9"	21'-6"
	NI-90	25'-7"	23'-7"	22'-6"	21'-3"	26'-3"	24'-3"	23'-1"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-9"	15'-4"	14'-6"	13'-5"	16'-9"	15'-4"	14'-6"	13'-5"
	NI-40x	18'-6"	17'-2"	16'-3"	15'-1"	18'-9"	17'-2"	16'-3"	15'-1"
	NI-60	18'-9"	17'-5"	16'-6"	15'-4"	19'-1"	17'-5"	16'-6"	15'-4"
	NI-80	20'-0"	18'-7"	17'-10"	16'-10"	20'-6"	19'-1"	18'-1"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-2"	20'-1"	18'-5"	17'-5"	16'-2"
	NI-40x	21'-8"	20'-2"	19'-3"	17'-8"	22'-3"	20'-5"	19'-3"	17'-8"
	NI-60	21'-11"	20'-5"	19'-6"	18'-3"	22'-6"	20'-10"	19'-8"	18'-3"
	NI-80	23'-5"	21'-9"	20'-9"	19'-8"	23'-11"	22'-3"	21'-3"	20'-0"
14"	NI-90	23'-11"	22'-2"	21'-1"	20'-0"	24'-4"	22'-8"	21'-8"	20'-6"
	NI-40x	24'-3"	22'-7"	21'-6"	19'-5"	24'-11"	23'-1"	21'-9"	19'-5"
	NI-60	24'-8"	22'-11"	21'-10"	20'-8"	25'-3"	23'-7"	22'-4"	20'-9"
	NI-80	26'-3"	24'-5"	23'-3"	22'-0"	26'-10"	25'-0"	23'-10"	22'-7"
16"	NI-90	26'-9"	24'-10"	23'-8"	22'-5"	27'-4"	25'-5"	24'-3"	22'-11"
	NI-60	27'-1"	25'-2"	24'-0"	22'-9"	27'-9"	26'-0"	24'-9"	23'-0"
	NI-80	28'-10"	26'-10"	25'-6"	24'-2"	29'-6"	27'-6"	26'-3"	24'-10"
	NI-90	29'-5"	27'-3"	26'-0"	24'-6"	30'-0"	27'-11"	26'-8"	25'-2"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S3.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-11"	16'-0"	15'-5"	14'-7"	17'-6"	16'-6"	15'-9"	14'-7"
	NI-40x	18'-2"	17'-1"	16'-5"	15'-5"	18'-9"	17'-6"	16'-11"	15'-5"
	NI-60	18'-5"	17'-3"	16'-7"	15'-11"	19'-0"	17'-8"	17'-1"	16'-4"
	NI-80	19'-10"	18'-4"	17'-7"	16'-10"	20'-4"	18'-10"	17'-11"	17'-3"
11-7/8"	NI-20	19'-5"	18'-0"	17'-4"	16'-7"	20'-2"	18'-10"	18'-0"	16'-7"
	NI-40x	21'-0"	19'-6"	18'-7"	17'-7"	21'-8"	20'-2"	19'-3"	17'-7"
	NI-60	21'-4"	19'-9"	18'-10"	17'-11"	22'-0"	20'-5"	19'-6"	18'-6"
	NI-80	22'-11"	21'-2"	20'-2"	19'-1"	23'-6"	21'-9"	20'-9"	19'-8"
14"	NI-90	23'-5"	21'-7"	20'-7"	19'-6"	24'-0"	22'-2"	21'-2"	20'-0"
	NI-40x	23'-4"	21'-7"	20'-7"	19'-4"	24'-1"	22'-5"	21'-5"	19'-4"
	NI-60	23'-8"	21'-11"	20'-11"	19'-10"	24'-5"	22'-9"	21'-8"	20'-7"
	NI-80	25'-5"	23'-6"	22'-5"	21'-3"	26'-2"	24'-3"	23'-1"	21'-10"
16"	NI-90	26'-0"	24'-0"	22'-10"	21'-7"	26'-8"	24'-8"	23'-6"	22'-3"
	NI-60	25'-10"	23'-11"	22'-10"	21'-7"	26'-8"	24'-9"	23'-8"	22'-6"
	NI-80	27'-9"	25'-7"	24'-5"	23'-1"	28'-6"	26'-5"	25'-2"	23'-10"
	NI-90	28'-3"	26'-1"	24'-10"	23'-6"	29'-0"	26'-10"	25'-7"	24'-3"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-3"	16'-9"	15'-9"	14'-7"	18'-3"	16'-9"	15'-9"	14'-7"
	NI-40x	20'-3"	18'-8"	17'-3"	15'-5"	20'-5"	18'-8"	17'-3"	15'-5"
	NI-60	20'-5"	19'-0"	17'-11"	16'-8"	20'-10"	19'-0"	17'-11"	16'-8"
	NI-80	21'-11"	20'-5"	19'-5"	18'-3"	22'-5"	20'-11"	19'-8"	18'-3"
11-7/8"	NI-20	21'-10"	20'-0"	18'-7"	16'-7"	21'-10"	20'-0"	18'-7"	16'-7"
	NI-40x	23'-8"	21'-7"	19'-9"	17'-7"	24'-4"	21'-7"	19'-9"	17'-7"
	NI-60	23'-11"	22'-4"	21'-3"	19'-11"	24'-7"	22'-8"	21'-4"	19'-11"
	NI-80	25'-7"	23'-10"	22'-8"	21'-6"	26'-2"	24'-5"	23'-4"	21'-9"
14"	NI-90	26'-2"	24'-3"	23'-2"	21'-11"	26'-8"	24'-10"	23'-9"	22'-4"
	NI-40x	26'-6"	23'-9"	21'-8"	19'-4"	27'-3"	23'-9"	21'-8"	19'-4"
	NI-60	26'-11"	25'-0"	23'-11"	22'-2"	27'-8"	25'-9"	24'-3"	22'-2"
	NI-80	28'-9"	26'-8"	25'-5"	24'-1"	29'-5"	27'-5"	26'-2"	24'-8"
16"	NI-90	29'-4"	27'-2"	25'-11"	24'-6"	29'-11"	27'-11"	26'-7"	25'-2"
	NI-60	29'-7"	27'-6"	26'-3"	23'-11"	30'-4"	28'-5"	26'-9"	23'-11"
	NI-80	31'-7"	29'-4"	27'-11"	26'-5"	32'-5"	30'-1"	28'-9"	27'-2"
	NI-90	32'-3"	29'-10"	28'-5"	26'-10"	33'-2"	30'-7"	29'-2"	27'-7"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S4.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-11"	15'-0"	14'-6"	13'-5"	16'-5"	15'-5"	14'-6"	13'-5"
	NI-40x	17'-0"	16'-0"	15'-5"	14'-10"	17'-5"	16'-5"	15'-10"	15'-2"
	NI-60	17'-2"	16'-2"	15'-7"	14'-11"	17'-7"	16'-7"	16'-0"	15'-4"
	NI-80	18'-3"	17'-1"	16'-5"	15'-9"	18'-8"	17'-5"	16'-9"	16'-1"
11-7/8"	NI-20	17'-11"	16'-11"	16'-3"	15'-8"	18'-7"	17'-5"	16'-10"	16'-2"
	NI-40x	19'-4"	17'-11"	17'-3"	16'-7"	19'-11"	18'-6"	17'-9"	17'-0"
	NI-60	19'-7"	18'-2"	17'-6"	16'-9"	20'-2"	18'-9"	17'-11"	17'-2"
	NI-80	21'-1"	19'-6"	18'-6"	17'-7"	21'-7"	20'-0"	19'-0"	18'-0"
14"	NI-90	21'-6"	19'-10"	18'-11"	17'-11"	22'-0"	20'-4"	19'-5"	18'-4"
	NI-40x	21'-5"	19'-11"	18'-11"	18'-0"	22'-1"	20'-7"	19'-7"	18'-7"
	NI-60	21'-10"	20'-2"	19'-3"	18'-3"	22'-6"	20'-10"	19'-11"	18'-10"
	NI-80	23'-5"	21'-7"	20'-7"	19'-5"	24'-0"	22'-3"	21'-2"	20'-0"
16"	NI-90	23'-10"	22'-1"	21'-0"	19'-10"	24'-5"	22'-7"	21'-6"	20'-4"
	NI-60	23'-9"	22'-0"	21'-0"	19'-10"	24'-6"	22'-9"	21'-8"	20'-7"
	NI-80	25'-6"	23'-7"	22'-5"	21'-2"	26'-2"	24'-3"	23'-1"	21'-10"
	NI-90	26'-0"	24'-0"	22'-10"	21'-6"	26'-7"	24'-8"	23'-5"	22'-2"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-6"	13'-5"	16'-10"	15'-5"	14'-6"	13'-5"
	NI-40x	18'-8"	17'-2"	16'-3"	15'-2"	18'-10"	17'-2"	16'-3"	15'-2"
	NI-60	18'-11"	17'-6"	16'-6"	15'-5"	19'-2"	17'-6"	16'-6"	15'-5"
	NI-80	20'-3"	18'-10"	17'-11"	16'-10"	20'-8"	19'-3"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-2"	20'-1"	18'-5"	17'-5"	16'-2"
	NI-40x	21'-10"	20'-4"	19'-4"	17'-8"	22'-5"	20'-6"	19'-4"	17'-8"
	NI-60	22'-1"	20'-7"	19'-8"	18'-4"	22'-8"	20'-10"	19'-8"	18'-4"
	NI-80	23'-8"	22'-0"	20'-11"	19'-10"	24'-1"	22'-6"	21'-6"	20'-0"
14"	NI-90	24'-1"	22'-5"	21'-4"	20'-2"	24'-7"	22'-11"	21'-10"	20'-7"
	NI-40x	24'-5"	22'-9"	21'-9"	19'-5"	25'-1"	23'-2"	21'-9"	19'-5"
	NI-60	24'-10"	23'-2"	22'-1"	20'-10"	25'-6"	23'-8"	22'-4"	20'-10"
	NI-80	26'-6"	24'-8"	23'-6"	22'-2"	27'-1"	25'-3"	24'-1"	22'-9"
16"	NI-90	27'-0"	25'-1"	23'-11"	22'-7"	27'-6"	25'-8"	24'-6"	23'-2"
	NI-60	27'-3"	25'-5"	24'-3"	22'-11"	28'-0"	26'-2"	24'-9"	23'-1"
	NI-80	29'-1"	27'-1"	25'-9"	24'-4"	29'-8"	27'-9"	26'-5"	25'-0"
	NI-90	29'-7"	27'-6"	26'-2"	24'-9"	30'-2"	28'-2"	26'-10"	25'-5"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S4.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-2"	16'-2"	15'-8"	14'-7"	17'-8"	16'-9"	15'-9"	14'-7"
	NI-40x	18'-5"	17'-3"	16'-8"	15'-5"	19'-0"	17'-9"	17'-1"	15'-5"
	NI-60	18'-8"	17'-5"	16'-10"	16'-1"	19'-3"	17'-11"	17'-3"	16'-6"
	NI-80	20'-1"	18'-7"	17'-9"	17'-0"	20'-7"	19'-1"	18'-3"	17'-5"
11-7/8"	NI-20	19'-8"	18'-3"	17'-7"	16'-7"	20'-6"	19'-1"	18'-3"	16'-7"
	NI-40x	21'-4"	19'-9"	18'-10"	17'-7"	22'-0"	20'-6"	19'-6"	17'-7"
	NI-60	21'-8"	20'-1"	19'-1"	18'-1"	22'-3"	20'-9"	19'-9"	18'-9"
	NI-80	23'-3"	21'-6"	20'-5"	19'-4"	23'-10"	22'-1"	21'-1"	19'-11"
	NI-90	23'-9"	21'-11"	20'-10"	19'-9"	24'-4"	22'-6"	21'-5"	20'-4"
14"	NI-40x	23'-8"	21'-11"	20'-11"	19'-4"	24'-5"	22'-9"	21'-8"	19'-4"
	NI-60	24'-1"	22'-3"	21'-3"	20'-1"	24'-10"	23'-1"	22'-0"	20'-10"
	NI-80	25'-10"	23'-10"	22'-9"	21'-6"	26'-6"	24'-7"	23'-5"	22'-2"
	NI-90	26'-4"	24'-4"	23'-2"	21'-11"	27'-0"	25'-0"	23'-10"	22'-6"
16"	NI-60	26'-3"	24'-3"	23'-2"	21'-11"	27'-1"	25'-2"	24'-0"	22'-9"
	NI-80	28'-2"	26'-0"	24'-9"	23'-5"	28'-10"	26'-9"	25'-6"	24'-2"
	NI-90	28'-8"	26'-6"	25'-2"	23'-10"	29'-5"	27'-3"	25'-11"	24'-6"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-4"	16'-9"	15'-9"	14'-7"	18'-4"	16'-9"	15'-9"	14'-7"
	NI-40x	20'-5"	18'-9"	17'-3"	15'-5"	20'-6"	18'-9"	17'-3"	15'-5"
	NI-60	20'-8"	19'-0"	18'-0"	16'-9"	20'-10"	19'-0"	18'-0"	16'-9"
	NI-80	22'-2"	20'-7"	19'-8"	18'-4"	22'-8"	20'-11"	19'-9"	18'-4"
11-7/8"	NI-20	21'-11"	20'-1"	18'-7"	16'-7"	21'-11"	20'-1"	18'-7"	16'-7"
	NI-40x	23'-10"	21'-7"	19'-9"	17'-7"	24'-5"	21'-7"	19'-9"	17'-7"
	NI-60	24'-2"	22'-6"	21'-5"	19'-11"	24'-10"	22'-8"	21'-5"	19'-11"
	NI-80	25'-10"	24'-1"	22'-11"	21'-8"	26'-5"	24'-8"	23'-5"	21'-9"
	NI-90	26'-4"	24'-6"	23'-4"	22'-1"	26'-11"	25'-1"	23'-11"	22'-4"
14"	NI-40x	26'-8"	23'-9"	21'-8"	19'-4"	27'-5"	23'-9"	21'-8"	19'-4"
	NI-60	27'-2"	25'-3"	24'-1"	22'-2"	27'-10"	25'-9"	24'-4"	22'-2"
	NI-80	29'-0"	27'-0"	25'-8"	24'-3"	29'-7"	27'-8"	26'-5"	24'-9"
	NI-90	29'-7"	27'-6"	26'-2"	24'-9"	30'-2"	28'-2"	26'-10"	25'-4"
16"	NI-60	29'-10"	27'-9"	26'-6"	23'-11"	30'-7"	28'-7"	26'-9"	23'-11"
	NI-80	31'-10"	29'-7"	28'-2"	26'-7"	32'-9"	30'-4"	29'-0"	27'-5"
	NI-90	32'-7"	30'-1"	28'-8"	27'-1"	33'-6"	30'-10"	29'-5"	27'-10"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S5.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-5"	14'-6"	13'-5"	17'-0"	15'-5"	14'-6"	13'-5"
	NI-40x	17'-9"	16'-9"	16'-2"	15'-3"	18'-2"	17'-2"	16'-5"	15'-3"
	NI-60	17'-11"	16'-11"	16'-3"	15'-6"	18'-5"	17'-3"	16'-8"	15'-6"
	NI-80	19'-3"	17'-10"	17'-2"	16'-5"	19'-8"	18'-3"	17'-6"	16'-9"
11-7/8"	NI-20	18'-11"	17'-8"	17'-0"	16'-2"	19'-7"	18'-3"	17'-6"	16'-2"
	NI-40x	20'-5"	19'-0"	18'-1"	17'-3"	21'-0"	19'-7"	18'-8"	17'-8"
	NI-60	20'-8"	19'-3"	18'-4"	17'-5"	21'-3"	19'-10"	18'-11"	17'-10"
	NI-80	22'-2"	20'-7"	19'-7"	18'-5"	22'-8"	21'-1"	20'-1"	18'-11"
14"	NI-90	22'-8"	21'-0"	19'-11"	18'-9"	23'-2"	21'-6"	20'-5"	19'-3"
	NI-40x	22'-7"	21'-0"	20'-0"	18'-10"	23'-3"	21'-8"	20'-8"	19'-5"
	NI-60	23'-0"	21'-4"	20'-4"	19'-2"	23'-8"	22'-0"	21'-0"	19'-10"
	NI-80	24'-8"	22'-10"	21'-8"	20'-5"	25'-3"	23'-5"	22'-4"	21'-0"
16"	NI-90	25'-2"	23'-3"	22'-1"	20'-10"	25'-8"	23'-10"	22'-8"	21'-5"
	NI-60	25'-1"	23'-3"	22'-1"	20'-10"	25'-9"	24'-0"	22'-11"	21'-7"
	NI-80	26'-10"	24'-10"	23'-7"	22'-3"	27'-6"	25'-6"	24'-3"	22'-11"
	NI-90	27'-4"	25'-4"	24'-1"	22'-7"	27'-11"	25'-11"	24'-8"	23'-3"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-0"	15'-5"	14'-6"	13'-5"	17'-0"	15'-5"	14'-6"	13'-5"
	NI-40x	19'-0"	17'-4"	16'-5"	15'-3"	19'-0"	17'-4"	16'-5"	15'-3"
	NI-60	19'-3"	17'-8"	16'-8"	15'-6"	19'-3"	17'-8"	16'-8"	15'-6"
	NI-80	20'-11"	19'-5"	18'-3"	17'-0"	21'-3"	19'-5"	18'-3"	17'-0"
11-7/8"	NI-20	20'-4"	18'-7"	17'-6"	16'-2"	20'-4"	18'-7"	17'-6"	16'-2"
	NI-40x	22'-7"	20'-8"	19'-6"	17'-8"	22'-7"	20'-8"	19'-6"	17'-8"
	NI-60	22'-10"	21'-0"	19'-10"	18'-6"	23'-0"	21'-0"	19'-10"	18'-6"
	NI-80	24'-5"	22'-9"	21'-8"	20'-2"	24'-11"	23'-0"	21'-8"	20'-2"
14"	NI-90	24'-11"	23'-3"	22'-2"	20'-9"	25'-4"	23'-8"	22'-3"	20'-9"
	NI-40x	25'-2"	23'-4"	21'-9"	19'-5"	25'-6"	23'-4"	21'-9"	19'-5"
	NI-60	25'-7"	23'-10"	22'-6"	21'-0"	26'-1"	23'-10"	22'-6"	21'-0"
	NI-80	27'-4"	25'-6"	24'-4"	22'-11"	27'-10"	26'-1"	24'-7"	22'-11"
16"	NI-90	27'-10"	26'-0"	24'-9"	23'-4"	28'-4"	26'-7"	25'-3"	23'-6"
	NI-60	28'-1"	26'-3"	24'-11"	23'-3"	28'-9"	26'-5"	24'-11"	23'-3"
	NI-80	29'-11"	27'-11"	26'-8"	25'-1"	30'-6"	28'-7"	27'-3"	25'-4"
	NI-90	30'-6"	28'-5"	27'-1"	25'-6"	31'-0"	29'-1"	27'-9"	25'-11"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S5.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	16'-10"	15'-9"	14'-7"	18'-6"	16'-10"	15'-9"	14'-7"
	NI-40x	19'-6"	18'-1"	17'-3"	15'-5"	20'-1"	18'-8"	17'-3"	15'-5"
	NI-60	19'-9"	18'-4"	17'-7"	16'-9"	20'-3"	18'-11"	18'-0"	16'-10"
	NI-80	21'-3"	19'-8"	18'-9"	17'-8"	21'-8"	20'-2"	19'-3"	18'-1"
11-7/8"	NI-20	20'-9"	19'-4"	18'-5"	16'-7"	21'-7"	20'-2"	18'-7"	16'-7"
	NI-40x	22'-6"	20'-11"	19'-9"	17'-7"	23'-2"	21'-7"	19'-9"	17'-7"
	NI-60	22'-10"	21'-2"	20'-2"	19'-0"	23'-6"	21'-10"	20'-10"	19'-8"
	NI-80	24'-6"	22'-8"	21'-7"	20'-4"	25'-1"	23'-3"	22'-2"	20'-11"
	NI-90	25'-0"	23'-2"	22'-0"	20'-9"	25'-7"	23'-9"	22'-7"	21'-4"
14"	NI-40x	24'-11"	23'-2"	21'-8"	19'-4"	25'-8"	23'-9"	21'-8"	19'-4"
	NI-60	25'-4"	23'-6"	22'-5"	21'-1"	26'-1"	24'-4"	23'-2"	21'-11"
	NI-80	27'-2"	25'-2"	24'-0"	22'-7"	27'-10"	25'-11"	24'-8"	23'-3"
	NI-90	27'-9"	25'-8"	24'-5"	23'-0"	28'-4"	26'-4"	25'-1"	23'-8"
16"	NI-60	27'-7"	25'-8"	24'-5"	23'-0"	28'-5"	26'-6"	25'-3"	23'-11"
	NI-80	29'-7"	27'-5"	26'-1"	24'-7"	30'-4"	28'-2"	26'-10"	25'-4"
	NI-90	30'-2"	27'-11"	26'-7"	25'-0"	30'-10"	28'-8"	27'-4"	25'-9"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-6"	16'-10"	15'-9"	14'-7"	18'-6"	16'-10"	15'-9"	14'-7"
	NI-40x	20'-8"	18'-11"	17'-3"	15'-5"	20'-8"	18'-11"	17'-3"	15'-5"
	NI-60	21'-0"	19'-2"	18'-1"	16'-10"	21'-0"	19'-2"	18'-1"	16'-10"
	NI-80	22'-11"	21'-1"	19'-11"	18'-6"	23'-1"	21'-1"	19'-11"	18'-6"
11-7/8"	NI-20	22'-1"	20'-3"	18'-7"	16'-7"	22'-1"	20'-3"	18'-7"	16'-7"
	NI-40x	24'-7"	21'-7"	19'-9"	17'-7"	24'-7"	21'-7"	19'-9"	17'-7"
	NI-60	25'-0"	22'-11"	21'-7"	20'-1"	25'-1"	22'-11"	21'-7"	20'-1"
	NI-80	26'-9"	24'-11"	23'-7"	22'-0"	27'-3"	25'-1"	23'-7"	22'-0"
	NI-90	27'-3"	25'-5"	24'-3"	22'-6"	27'-10"	25'-9"	24'-3"	22'-6"
14"	NI-40x	27'-5"	23'-9"	21'-8"	19'-4"	27'-5"	23'-9"	21'-8"	19'-4"
	NI-60	28'-0"	26'-0"	24'-6"	22'-2"	28'-5"	26'-0"	24'-6"	22'-2"
	NI-80	29'-11"	27'-11"	26'-7"	24'-11"	30'-6"	28'-5"	26'-9"	24'-11"
	NI-90	30'-6"	28'-5"	27'-1"	25'-6"	31'-1"	29'-1"	27'-6"	25'-6"
16"	NI-60	30'-8"	28'-9"	26'-9"	23'-11"	31'-6"	28'-9"	26'-9"	23'-11"
	NI-80	33'-1"	30'-7"	29'-2"	27'-6"	34'-0"	31'-4"	29'-8"	27'-7"
	NI-90	33'-11"	31'-2"	29'-8"	28'-0"	34'-10"	31'-11"	30'-5"	28'-3"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S6.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-1"	-
	NI-80	17'-1"	16'-1"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-4"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-6"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-9"	17'-6"	16'-11"	-
	NI-80	19'-6"	18'-0"	17'-4"	-	20'-1"	18'-7"	17'-9"	-
	NI-90	19'-11"	18'-4"	17'-8"	-	20'-5"	18'-11"	18'-1"	-
14"	NI-40x	19'-10"	18'-4"	17'-8"	-	20'-6"	19'-1"	18'-3"	-
	NI-60	20'-2"	18'-8"	17'-11"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-8"	20'-0"	19'-1"	-	22'-4"	20'-8"	19'-9"	-
	NI-90	22'-1"	20'-5"	19'-6"	-	22'-9"	21'-0"	20'-1"	-
16"	NI-60	22'-0"	20'-4"	19'-6"	-	22'-9"	21'-1"	20'-2"	-
	NI-80	23'-7"	21'-10"	20'-10"	-	24'-4"	22'-6"	21'-6"	-
	NI-90	24'-1"	22'-2"	21'-2"	-	24'-9"	22'-11"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-6"	15'-1"	14'-3"	-	16'-6"	15'-1"	14'-3"	-
	NI-40x	17'-9"	16'-10"	15'-11"	-	18'-2"	16'-11"	15'-11"	-
	NI-60	17'-11"	16'-11"	16'-2"	-	18'-5"	17'-2"	16'-2"	-
	NI-80	19'-3"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	18'-0"	17'-1"	-	19'-9"	18'-1"	17'-1"	-
	NI-40x	20'-10"	19'-4"	18'-6"	-	21'-5"	19'-11"	19'-0"	-
	NI-60	21'-1"	19'-7"	18'-8"	-	21'-8"	20'-2"	19'-3"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
14"	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
	NI-40x	23'-5"	21'-8"	20'-9"	-	24'-0"	22'-5"	21'-5"	-
	NI-60	23'-9"	22'-0"	21'-0"	-	24'-5"	22'-8"	21'-8"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
16"	NI-90	25'-10"	23'-11"	22'-9"	-	26'-5"	24'-6"	23'-4"	-
	NI-60	26'-2"	24'-3"	23'-2"	-	26'-11"	25'-0"	23'-11"	-
	NI-80	27'-11"	25'-10"	24'-7"	-	28'-7"	26'-6"	25'-3"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S6.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-8"	-	16'-7"	15'-8"	15'-2"	-
	NI-40x	17'-2"	16'-2"	15'-8"	-	17'-8"	16'-8"	16'-1"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-7"	17'-4"	16'-9"	-	19'-2"	17'-9"	17'-2"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-6"	-	18'-11"	17'-8"	17'-1"	-
	NI-40x	19'-8"	18'-3"	17'-7"	-	20'-5"	18'-11"	18'-2"	-
	NI-60	20'-0"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-5"	-
	NI-80	21'-6"	19'-11"	19'-0"	-	22'-2"	20'-6"	19'-7"	-
14"	NI-90	22'-0"	20'-4"	19'-5"	-	22'-7"	20'-11"	20'-0"	-
	NI-40x	21'-10"	20'-3"	19'-5"	-	22'-8"	21'-1"	20'-2"	-
	NI-60	22'-3"	20'-7"	19'-9"	-	23'-0"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-10"	-
16"	NI-90	24'-5"	22'-7"	21'-6"	-	25'-2"	23'-3"	22'-3"	-
	NI-60	24'-3"	22'-6"	21'-6"	-	25'-2"	23'-4"	22'-4"	-
	NI-80	26'-1"	24'-1"	23'-0"	-	26'-11"	24'-11"	23'-9"	-
	NI-90	26'-7"	24'-7"	23'-5"	-	27'-5"	25'-4"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-10"	16'-5"	15'-6"	-	17'-11"	16'-5"	15'-6"	-
	NI-40x	19'-4"	18'-0"	17'-3"	-	19'-11"	18'-4"	17'-3"	-
	NI-60	19'-7"	18'-2"	17'-6"	-	20'-2"	18'-8"	17'-7"	-
	NI-80	21'-0"	19'-6"	18'-8"	-	21'-6"	20'-0"	19'-1"	-
11-7/8"	NI-20	21'-0"	19'-7"	18'-7"	-	21'-6"	19'-8"	18'-7"	-
	NI-40x	22'-8"	21'-1"	19'-9"	-	23'-5"	21'-7"	19'-9"	-
	NI-60	23'-0"	21'-4"	20'-5"	-	23'-8"	22'-1"	21'-0"	-
	NI-80	24'-8"	22'-10"	21'-9"	-	25'-3"	23'-5"	22'-5"	-
14"	NI-90	25'-2"	23'-3"	22'-3"	-	25'-9"	23'-11"	22'-10"	-
	NI-40x	25'-6"	23'-8"	21'-8"	-	26'-3"	23'-9"	21'-8"	-
	NI-60	25'-11"	24'-0"	22'-11"	-	26'-8"	24'-10"	23'-9"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
16"	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-7"	-
	NI-60	28'-7"	26'-6"	25'-3"	-	29'-4"	27'-4"	26'-2"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-2"	29'-0"	27'-8"	-
	NI-90	31'-1"	28'-9"	27'-4"	-	31'-9"	29'-6"	28'-2"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S7.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-10"	15'-0"	14'-5"	13'-5"	16'-4"	15'-5"	14'-6"	13'-5"
	NI-40x	16'-11"	15'-11"	15'-4"	14'-9"	17'-4"	16'-4"	15'-9"	15'-1"
	NI-60	17'-1"	16'-1"	15'-6"	14'-10"	17'-6"	16'-6"	15'-11"	15'-3"
	NI-80	18'-1"	17'-0"	16'-4"	15'-8"	18'-7"	17'-4"	16'-8"	16'-0"
11-7/8"	NI-20	17'-10"	16'-10"	16'-2"	15'-7"	18'-5"	17'-4"	16'-9"	16'-1"
	NI-40x	19'-3"	17'-10"	17'-2"	16'-6"	19'-10"	18'-5"	17'-8"	16'-11"
	NI-60	19'-6"	18'-1"	17'-4"	16'-8"	20'-1"	18'-8"	17'-10"	17'-1"
	NI-80	20'-11"	19'-4"	18'-5"	17'-7"	21'-5"	19'-10"	18'-11"	17'-11"
	NI-90	21'-4"	19'-9"	18'-9"	17'-10"	21'-10"	20'-3"	19'-3"	18'-3"
14"	NI-40x	21'-4"	19'-9"	18'-10"	17'-11"	22'-0"	20'-5"	19'-6"	18'-6"
	NI-60	21'-8"	20'-1"	19'-2"	18'-2"	22'-4"	20'-9"	19'-9"	18'-9"
	NI-80	23'-3"	21'-6"	20'-5"	19'-4"	23'-10"	22'-1"	21'-0"	19'-11"
	NI-90	23'-9"	21'-11"	20'-10"	19'-8"	24'-3"	22'-6"	21'-5"	20'-3"
16"	NI-60	23'-7"	21'-10"	20'-10"	19'-9"	24'-4"	22'-7"	21'-7"	20'-5"
	NI-80	25'-4"	23'-5"	22'-3"	21'-1"	26'-0"	24'-1"	22'-11"	21'-8"
	NI-90	25'-10"	23'-10"	22'-8"	21'-5"	26'-5"	24'-6"	23'-4"	22'-0"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-6"	13'-5"	16'-10"	15'-5"	14'-6"	13'-5"
	NI-40x	18'-7"	17'-2"	16'-3"	15'-2"	18'-10"	17'-2"	16'-3"	15'-2"
	NI-60	18'-10"	17'-6"	16'-6"	15'-5"	19'-1"	17'-6"	16'-6"	15'-5"
	NI-80	20'-2"	18'-9"	17'-11"	16'-10"	20'-7"	19'-2"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-2"	20'-1"	18'-5"	17'-5"	16'-2"
	NI-40x	21'-9"	20'-3"	19'-4"	17'-8"	22'-4"	20'-5"	19'-4"	17'-8"
	NI-60	22'-0"	20'-6"	19'-7"	18'-4"	22'-7"	20'-10"	19'-8"	18'-4"
	NI-80	23'-6"	21'-10"	20'-10"	19'-9"	24'-0"	22'-5"	21'-4"	20'-0"
	NI-90	24'-0"	22'-4"	21'-3"	20'-1"	24'-6"	22'-10"	21'-9"	20'-7"
14"	NI-40x	24'-4"	22'-8"	21'-8"	19'-5"	25'-0"	23'-2"	21'-9"	19'-5"
	NI-60	24'-9"	23'-0"	22'-0"	20'-9"	25'-5"	23'-8"	22'-4"	20'-10"
	NI-80	26'-5"	24'-6"	23'-4"	22'-1"	27'-0"	25'-2"	24'-0"	22'-8"
	NI-90	26'-11"	25'-0"	23'-10"	22'-6"	27'-5"	25'-7"	24'-5"	23'-1"
16"	NI-60	27'-2"	25'-4"	24'-2"	22'-10"	27'-11"	26'-1"	24'-9"	23'-1"
	NI-80	29'-0"	26'-11"	25'-8"	24'-3"	29'-7"	27'-7"	26'-4"	24'-11"
	NI-90	29'-6"	27'-5"	26'-1"	24'-8"	30'-1"	28'-1"	26'-9"	25'-4"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – S7.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 15 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-1"	16'-1"	15'-7"	14'-7"	17'-7"	16'-8"	15'-9"	14'-7"
	NI-40x	18'-4"	17'-2"	16'-7"	15'-5"	18'-11"	17'-8"	17'-0"	15'-5"
	NI-60	18'-7"	17'-4"	16'-9"	16'-1"	19'-1"	17'-9"	17'-2"	16'-6"
	NI-80	20'-0"	18'-6"	17'-8"	16'-11"	20'-6"	19'-0"	18'-1"	17'-4"
11-7/8"	NI-20	19'-7"	18'-2"	17'-6"	16'-7"	20'-4"	18'-11"	18'-2"	16'-7"
	NI-40x	21'-2"	19'-8"	18'-9"	17'-7"	21'-10"	20'-4"	19'-5"	17'-7"
	NI-60	21'-6"	19'-11"	19'-0"	18'-0"	22'-2"	20'-7"	19'-8"	18'-8"
	NI-80	23'-1"	21'-4"	20'-4"	19'-3"	23'-8"	21'-11"	20'-11"	19'-10"
14"	NI-90	23'-7"	21'-9"	20'-9"	19'-8"	24'-2"	22'-5"	21'-4"	20'-2"
	NI-40x	23'-6"	21'-9"	20'-9"	19'-4"	24'-3"	22'-7"	21'-7"	19'-4"
	NI-60	23'-11"	22'-2"	21'-1"	20'-0"	24'-8"	22'-11"	21'-10"	20'-9"
	NI-80	25'-8"	23'-9"	22'-7"	21'-4"	26'-4"	24'-5"	23'-3"	22'-0"
16"	NI-90	26'-2"	24'-2"	23'-0"	21'-9"	26'-10"	24'-10"	23'-8"	22'-5"
	NI-60	26'-1"	24'-1"	23'-0"	21'-9"	26'-11"	25'-0"	23'-10"	22'-7"
	NI-80	27'-11"	25'-10"	24'-7"	23'-3"	28'-8"	26'-7"	25'-4"	24'-0"
NI-90	28'-6"	26'-4"	25'-0"	23'-8"	29'-3"	27'-1"	25'-9"	24'-5"	

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-4"	16'-9"	15'-9"	14'-7"	18'-4"	16'-9"	15'-9"	14'-7"
	NI-40x	20'-4"	18'-9"	17'-3"	15'-5"	20'-6"	18'-9"	17'-3"	15'-5"
	NI-60	20'-7"	19'-0"	17'-11"	16'-9"	20'-10"	19'-0"	17'-11"	16'-9"
	NI-80	22'-1"	20'-6"	19'-7"	18'-4"	22'-7"	20'-11"	19'-9"	18'-4"
11-7/8"	NI-20	21'-11"	20'-1"	18'-7"	16'-7"	21'-11"	20'-1"	18'-7"	16'-7"
	NI-40x	23'-9"	21'-7"	19'-9"	17'-7"	24'-5"	21'-7"	19'-9"	17'-7"
	NI-60	24'-1"	22'-5"	21'-5"	19'-11"	24'-9"	22'-8"	21'-5"	19'-11"
	NI-80	25'-9"	23'-11"	22'-10"	21'-7"	26'-4"	24'-7"	23'-5"	21'-9"
14"	NI-90	26'-3"	24'-5"	23'-3"	22'-0"	26'-10"	25'-0"	23'-10"	22'-4"
	NI-40x	26'-7"	23'-9"	21'-8"	19'-4"	27'-4"	23'-9"	21'-8"	19'-4"
	NI-60	27'-0"	25'-2"	24'-0"	22'-2"	27'-9"	25'-9"	24'-4"	22'-2"
	NI-80	28'-11"	26'-10"	25'-7"	24'-2"	29'-6"	27'-7"	26'-4"	24'-9"
16"	NI-90	29'-5"	27'-4"	26'-1"	24'-7"	30'-1"	28'-0"	26'-9"	25'-4"
	NI-60	29'-8"	27'-8"	26'-4"	23'-11"	30'-6"	28'-7"	26'-9"	23'-11"
	NI-80	31'-8"	29'-6"	28'-1"	26'-6"	32'-7"	30'-3"	28'-10"	27'-4"
NI-90	32'-5"	30'-0"	28'-7"	27'-0"	33'-4"	30'-9"	29'-4"	27'-9"	

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M1.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-0"	-
	NI-80	17'-0"	16'-0"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-3"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-5"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-8"	17'-6"	16'-11"	-
	NI-80	19'-5"	17'-11"	17'-4"	-	20'-0"	18'-6"	17'-9"	-
14"	NI-90	19'-10"	18'-4"	17'-7"	-	20'-5"	18'-10"	18'-0"	-
	NI-40x	19'-9"	18'-4"	17'-8"	-	20'-6"	19'-0"	18'-3"	-
	NI-60	20'-1"	18'-7"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-7"	19'-11"	19'-1"	-	22'-3"	20'-7"	19'-8"	-
16"	NI-90	22'-0"	20'-4"	19'-5"	-	22'-8"	21'-0"	20'-0"	-
	NI-60	21'-11"	20'-4"	19'-5"	-	22'-8"	21'-1"	20'-2"	-
	NI-80	23'-6"	21'-9"	20'-9"	-	24'-3"	22'-5"	21'-5"	-
	NI-90	23'-11"	22'-1"	21'-2"	-	24'-8"	22'-10"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-7"	15'-2"	14'-4"	-	16'-7"	15'-2"	14'-4"	-
	NI-40x	17'-9"	16'-10"	16'-1"	-	18'-3"	17'-0"	16'-1"	-
	NI-60	17'-11"	16'-11"	16'-4"	-	18'-5"	17'-3"	16'-4"	-
	NI-80	19'-2"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	18'-0"	17'-2"	-	19'-11"	18'-2"	17'-2"	-
	NI-40x	20'-10"	19'-4"	18'-6"	-	21'-5"	19'-11"	19'-0"	-
	NI-60	21'-1"	19'-7"	18'-9"	-	21'-8"	20'-2"	19'-4"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
14"	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
	NI-40x	23'-5"	21'-9"	20'-9"	-	24'-1"	22'-5"	20'-11"	-
	NI-60	23'-9"	22'-1"	21'-1"	-	24'-5"	22'-9"	21'-9"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
16"	NI-90	25'-10"	23'-11"	22'-10"	-	26'-5"	24'-6"	23'-5"	-
	NI-60	26'-3"	24'-3"	23'-2"	-	26'-11"	25'-1"	23'-11"	-
	NI-80	27'-11"	25'-10"	24'-8"	-	28'-7"	26'-6"	25'-4"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M1.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-8"	-	16'-7"	15'-8"	15'-2"	-
	NI-40x	17'-2"	16'-2"	15'-8"	-	17'-8"	16'-8"	16'-1"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-6"	17'-4"	16'-9"	-	19'-1"	17'-9"	17'-1"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-6"	-	18'-11"	17'-8"	17'-1"	-
	NI-40x	19'-8"	18'-3"	17'-7"	-	20'-4"	18'-11"	18'-2"	-
	NI-60	19'-11"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-4"	-
	NI-80	21'-5"	19'-10"	19'-0"	-	22'-1"	20'-6"	19'-7"	-
	NI-90	21'-11"	20'-3"	19'-4"	-	22'-6"	20'-10"	19'-11"	-
14"	NI-40x	21'-9"	20'-3"	19'-4"	-	22'-7"	21'-0"	20'-2"	-
	NI-60	22'-2"	20'-7"	19'-8"	-	23'-0"	21'-4"	20'-5"	-
	NI-80	23'-10"	22'-0"	21'-1"	-	24'-7"	22'-9"	21'-9"	-
	NI-90	24'-4"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-
16"	NI-60	24'-2"	22'-5"	21'-5"	-	25'-1"	23'-4"	22'-4"	-
	NI-80	26'-0"	24'-0"	22'-11"	-	26'-10"	24'-10"	23'-9"	-
	NI-90	26'-6"	24'-5"	23'-4"	-	27'-4"	25'-3"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	16'-6"	15'-8"	-	18'-1"	16'-6"	15'-8"	-
	NI-40x	19'-4"	18'-0"	16'-8"	-	19'-11"	18'-3"	16'-8"	-
	NI-60	19'-7"	18'-2"	17'-6"	-	20'-2"	18'-9"	17'-9"	-
	NI-80	21'-0"	19'-6"	18'-8"	-	21'-6"	20'-0"	19'-2"	-
11-7/8"	NI-20	21'-1"	19'-7"	17'-11"	-	21'-8"	19'-8"	17'-11"	-
	NI-40x	22'-9"	20'-10"	19'-0"	-	23'-5"	20'-10"	19'-0"	-
	NI-60	23'-0"	21'-4"	20'-5"	-	23'-8"	22'-1"	21'-2"	-
	NI-80	24'-7"	22'-10"	21'-10"	-	25'-3"	23'-5"	22'-5"	-
	NI-90	25'-1"	23'-3"	22'-3"	-	25'-9"	23'-10"	22'-10"	-
14"	NI-40x	25'-6"	22'-10"	20'-10"	-	26'-4"	22'-10"	20'-10"	-
	NI-60	25'-11"	24'-1"	23'-0"	-	26'-8"	24'-10"	23'-9"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-7"	-
16"	NI-60	28'-7"	26'-6"	25'-3"	-	29'-5"	27'-4"	25'-9"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-3"	29'-0"	27'-8"	-
	NI-90	31'-0"	28'-9"	27'-4"	-	31'-9"	29'-6"	28'-2"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M2.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-1"	14'-3"	13'-10"	-	15'-7"	14'-9"	14'-3"	-
	NI-40x	16'-2"	15'-3"	14'-8"	-	16'-7"	15'-8"	15'-1"	-
	NI-60	16'-4"	15'-4"	14'-10"	-	16'-9"	15'-9"	15'-3"	-
	NI-80	17'-3"	16'-3"	15'-8"	-	17'-8"	16'-7"	16'-0"	-
11-7/8"	NI-20	17'-0"	16'-0"	15'-6"	-	17'-6"	16'-7"	16'-0"	-
	NI-40x	18'-2"	17'-1"	16'-6"	-	18'-9"	17'-6"	16'-11"	-
	NI-60	18'-5"	17'-3"	16'-8"	-	19'-0"	17'-8"	17'-1"	-
	NI-80	19'-9"	18'-3"	17'-7"	-	20'-4"	18'-10"	18'-0"	-
14"	NI-90	20'-2"	18'-8"	17'-10"	-	20'-9"	19'-2"	18'-4"	-
	NI-40x	20'-1"	18'-8"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-60	20'-6"	18'-11"	18'-2"	-	21'-2"	19'-8"	18'-9"	-
	NI-80	21'-11"	20'-3"	19'-4"	-	22'-7"	20'-11"	20'-0"	-
16"	NI-90	22'-5"	20'-8"	19'-9"	-	23'-0"	21'-4"	20'-4"	-
	NI-60	22'-4"	20'-8"	19'-9"	-	23'-1"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-9"	-
	NI-90	24'-5"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-3"	14'-5"	-	16'-8"	15'-3"	14'-5"	-
	NI-40x	17'-11"	17'-0"	16'-1"	-	18'-5"	17'-1"	16'-1"	-
	NI-60	18'-2"	17'-1"	16'-4"	-	18'-8"	17'-4"	16'-4"	-
	NI-80	19'-5"	18'-0"	17'-5"	-	19'-10"	18'-5"	17'-8"	-
11-7/8"	NI-20	19'-7"	18'-2"	17'-3"	-	19'-11"	18'-3"	17'-3"	-
	NI-40x	21'-1"	19'-7"	18'-8"	-	21'-8"	20'-2"	19'-0"	-
	NI-60	21'-4"	19'-9"	18'-11"	-	21'-11"	20'-5"	19'-6"	-
	NI-80	22'-9"	21'-1"	20'-2"	-	23'-3"	21'-8"	20'-8"	-
14"	NI-90	23'-3"	21'-6"	20'-6"	-	23'-9"	22'-0"	21'-0"	-
	NI-40x	23'-8"	21'-11"	20'-11"	-	24'-4"	22'-8"	20'-11"	-
	NI-60	24'-0"	22'-3"	21'-3"	-	24'-8"	22'-11"	21'-11"	-
	NI-80	25'-7"	23'-9"	22'-7"	-	26'-2"	24'-4"	23'-3"	-
16"	NI-90	26'-1"	24'-2"	23'-0"	-	26'-8"	24'-9"	23'-7"	-
	NI-60	26'-5"	24'-6"	23'-5"	-	27'-2"	25'-3"	24'-2"	-
	NI-80	28'-2"	26'-1"	24'-10"	-	28'-10"	26'-9"	25'-6"	-
	NI-90	28'-8"	26'-6"	25'-3"	-	29'-3"	27'-2"	25'-11"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M2.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-3"	15'-4"	14'-10"	-	16'-10"	15'-11"	15'-5"	-
	NI-40x	17'-5"	16'-5"	15'-10"	-	17'-11"	16'-11"	16'-4"	-
	NI-60	17'-7"	16'-7"	16'-0"	-	18'-1"	17'-0"	16'-5"	-
	NI-80	18'-10"	17'-6"	16'-11"	-	19'-5"	18'-0"	17'-4"	-
11-7/8"	NI-20	18'-5"	17'-3"	16'-9"	-	19'-3"	17'-11"	17'-4"	-
	NI-40x	20'-0"	18'-7"	17'-9"	-	20'-8"	19'-3"	18'-5"	-
	NI-60	20'-3"	18'-10"	18'-0"	-	21'-0"	19'-6"	18'-8"	-
	NI-80	21'-10"	20'-2"	19'-3"	-	22'-5"	20'-10"	19'-10"	-
14"	NI-90	22'-3"	20'-7"	19'-8"	-	22'-11"	21'-2"	20'-3"	-
	NI-40x	22'-2"	20'-7"	19'-8"	-	23'-0"	21'-4"	20'-6"	-
	NI-60	22'-7"	20'-11"	20'-0"	-	23'-4"	21'-8"	20'-9"	-
	NI-80	24'-3"	22'-5"	21'-5"	-	25'-0"	23'-2"	22'-1"	-
16"	NI-90	24'-9"	22'-10"	21'-10"	-	25'-6"	23'-7"	22'-6"	-
	NI-60	24'-7"	22'-10"	21'-9"	-	25'-6"	23'-8"	22'-8"	-
	NI-80	26'-5"	24'-5"	23'-4"	-	27'-3"	25'-3"	24'-1"	-
	NI-90	26'-11"	24'-11"	23'-9"	-	27'-9"	25'-8"	24'-6"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-1"	16'-7"	15'-8"	-	18'-1"	16'-7"	15'-8"	-
	NI-40x	19'-7"	18'-3"	16'-8"	-	20'-2"	18'-3"	16'-8"	-
	NI-60	19'-10"	18'-5"	17'-8"	-	20'-5"	18'-10"	17'-9"	-
	NI-80	21'-3"	19'-8"	18'-10"	-	21'-9"	20'-3"	19'-4"	-
11-7/8"	NI-20	21'-4"	19'-8"	17'-11"	-	21'-9"	19'-8"	17'-11"	-
	NI-40x	23'-0"	20'-10"	19'-0"	-	23'-8"	20'-10"	19'-0"	-
	NI-60	23'-3"	21'-7"	20'-8"	-	23'-11"	22'-4"	21'-3"	-
	NI-80	24'-11"	23'-1"	22'-0"	-	25'-6"	23'-8"	22'-8"	-
14"	NI-90	25'-5"	23'-6"	22'-5"	-	26'-0"	24'-1"	23'-0"	-
	NI-40x	25'-9"	22'-10"	20'-10"	-	26'-5"	22'-10"	20'-10"	-
	NI-60	26'-2"	24'-4"	23'-2"	-	26'-11"	25'-1"	23'-11"	-
	NI-80	28'-0"	25'-11"	24'-9"	-	28'-8"	26'-8"	25'-5"	-
16"	NI-90	28'-6"	26'-5"	25'-2"	-	29'-2"	27'-1"	25'-10"	-
	NI-60	28'-10"	26'-9"	25'-6"	-	29'-8"	27'-8"	25'-9"	-
	NI-80	30'-9"	28'-6"	27'-2"	-	31'-6"	29'-3"	27'-11"	-
	NI-90	31'-4"	29'-0"	27'-8"	-	32'-1"	29'-9"	28'-5"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M3.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-9"	14'-10"	14'-4"	13'-5"	16'-2"	15'-4"	14'-6"	13'-5"
	NI-40x	16'-10"	15'-10"	15'-3"	14'-8"	17'-2"	16'-3"	15'-8"	14'-11"
	NI-60	16'-11"	16'-0"	15'-5"	14'-9"	17'-4"	16'-4"	15'-9"	15'-2"
	NI-80	18'-0"	16'-11"	16'-3"	15'-7"	18'-5"	17'-3"	16'-7"	15'-11"
11-7/8"	NI-20	17'-8"	16'-8"	16'-1"	15'-6"	18'-3"	17'-3"	16'-7"	16'-0"
	NI-40x	19'-1"	17'-9"	17'-1"	16'-5"	19'-8"	18'-3"	17'-6"	16'-10"
	NI-60	19'-4"	17'-11"	17'-3"	16'-7"	19'-11"	18'-6"	17'-8"	17'-0"
	NI-80	20'-9"	19'-2"	18'-3"	17'-5"	21'-3"	19'-8"	18'-9"	17'-10"
14"	NI-90	21'-2"	19'-7"	18'-8"	17'-9"	21'-8"	20'-1"	19'-1"	18'-1"
	NI-40x	21'-2"	19'-7"	18'-8"	17'-9"	21'-10"	20'-3"	19'-4"	18'-4"
	NI-60	21'-6"	19'-11"	19'-0"	18'-0"	22'-2"	20'-7"	19'-8"	18'-8"
	NI-80	23'-1"	21'-4"	20'-3"	19'-3"	23'-8"	21'-11"	20'-10"	19'-9"
16"	NI-90	23'-6"	21'-9"	20'-8"	19'-7"	24'-1"	22'-4"	21'-3"	20'-1"
	NI-60	23'-5"	21'-8"	20'-8"	19'-7"	24'-2"	22'-5"	21'-5"	20'-4"
	NI-80	25'-1"	23'-2"	22'-1"	20'-11"	25'-9"	23'-10"	22'-9"	21'-6"
	NI-90	25'-7"	23'-7"	22'-6"	21'-3"	26'-3"	24'-3"	23'-1"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-9"	15'-4"	14'-6"	13'-5"	16'-9"	15'-4"	14'-6"	13'-5"
	NI-40x	18'-6"	17'-2"	16'-3"	14'-11"	18'-9"	17'-2"	16'-3"	14'-11"
	NI-60	18'-9"	17'-5"	16'-6"	15'-4"	19'-1"	17'-5"	16'-6"	15'-4"
	NI-80	20'-0"	18'-7"	17'-10"	16'-10"	20'-6"	19'-1"	18'-1"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-1"	20'-1"	18'-5"	17'-5"	16'-1"
	NI-40x	21'-8"	20'-2"	19'-0"	17'-0"	22'-3"	20'-5"	19'-0"	17'-0"
	NI-60	21'-11"	20'-5"	19'-6"	18'-3"	22'-6"	20'-10"	19'-8"	18'-3"
	NI-80	23'-5"	21'-9"	20'-9"	19'-8"	23'-11"	22'-3"	21'-3"	20'-0"
14"	NI-90	23'-11"	22'-2"	21'-1"	20'-0"	24'-4"	22'-8"	21'-8"	20'-6"
	NI-40x	24'-3"	22'-7"	20'-11"	18'-8"	24'-11"	22'-11"	20'-11"	18'-8"
	NI-60	24'-8"	22'-11"	21'-10"	20'-8"	25'-3"	23'-7"	22'-4"	20'-9"
	NI-80	26'-3"	24'-5"	23'-3"	22'-0"	26'-10"	25'-0"	23'-10"	22'-7"
16"	NI-90	26'-9"	24'-10"	23'-8"	22'-5"	27'-4"	25'-5"	24'-3"	22'-11"
	NI-60	27'-1"	25'-2"	24'-0"	22'-9"	27'-9"	26'-0"	24'-9"	23'-0"
	NI-80	28'-10"	26'-10"	25'-6"	24'-2"	29'-6"	27'-6"	26'-3"	24'-10"
	NI-90	29'-5"	27'-3"	26'-0"	24'-6"	30'-0"	27'-11"	26'-8"	25'-2"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M3.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-11"	16'-0"	15'-5"	14'-0"	17'-6"	16'-6"	15'-8"	14'-0"
	NI-40x	18'-2"	17'-1"	16'-5"	14'-10"	18'-9"	17'-6"	16'-8"	14'-10"
	NI-60	18'-5"	17'-3"	16'-7"	15'-11"	19'-0"	17'-8"	17'-1"	16'-4"
	NI-80	19'-10"	18'-4"	17'-7"	16'-10"	20'-4"	18'-10"	17'-11"	17'-3"
11-7/8"	NI-20	19'-5"	18'-0"	17'-4"	16'-0"	20'-2"	18'-10"	17'-11"	16'-0"
	NI-40x	21'-0"	19'-6"	18'-7"	16'-11"	21'-8"	20'-2"	19'-0"	16'-11"
	NI-60	21'-4"	19'-9"	18'-10"	17'-11"	22'-0"	20'-5"	19'-6"	18'-6"
	NI-80	22'-11"	21'-2"	20'-2"	19'-1"	23'-6"	21'-9"	20'-9"	19'-8"
14"	NI-90	23'-5"	21'-7"	20'-7"	19'-6"	24'-0"	22'-2"	21'-2"	20'-0"
	NI-40x	23'-4"	21'-7"	20'-7"	18'-7"	24'-1"	22'-5"	20'-10"	18'-7"
	NI-60	23'-8"	21'-11"	20'-11"	19'-10"	24'-5"	22'-9"	21'-8"	20'-7"
	NI-80	25'-5"	23'-6"	22'-5"	21'-3"	26'-2"	24'-3"	23'-1"	21'-10"
16"	NI-90	26'-0"	24'-0"	22'-10"	21'-7"	26'-8"	24'-8"	23'-6"	22'-3"
	NI-60	25'-10"	23'-11"	22'-10"	21'-7"	26'-8"	24'-9"	23'-8"	22'-6"
	NI-80	27'-9"	25'-7"	24'-5"	23'-1"	28'-6"	26'-5"	25'-2"	23'-10"
	NI-90	28'-3"	26'-1"	24'-10"	23'-6"	29'-0"	26'-10"	25'-7"	24'-3"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-3"	16'-9"	15'-8"	14'-0"	18'-3"	16'-9"	15'-8"	14'-0"
	NI-40x	20'-3"	18'-3"	16'-8"	14'-10"	20'-5"	18'-3"	16'-8"	14'-10"
	NI-60	20'-5"	19'-0"	17'-11"	16'-8"	20'-10"	19'-0"	17'-11"	16'-8"
	NI-80	21'-11"	20'-5"	19'-5"	17'-7"	22'-5"	20'-11"	19'-8"	17'-7"
11-7/8"	NI-20	21'-10"	19'-8"	17'-11"	16'-0"	21'-10"	19'-8"	17'-11"	16'-0"
	NI-40x	23'-8"	20'-10"	19'-0"	16'-11"	24'-1"	20'-10"	19'-0"	16'-11"
	NI-60	23'-11"	22'-4"	21'-3"	19'-5"	24'-7"	22'-8"	21'-4"	19'-5"
	NI-80	25'-7"	23'-10"	22'-8"	21'-6"	26'-2"	24'-5"	23'-4"	21'-9"
14"	NI-90	26'-2"	24'-3"	23'-2"	21'-11"	26'-8"	24'-10"	23'-9"	22'-4"
	NI-40x	26'-5"	22'-10"	20'-10"	18'-7"	26'-5"	22'-10"	20'-10"	18'-7"
	NI-60	26'-11"	25'-0"	23'-11"	21'-4"	27'-8"	25'-9"	23'-11"	21'-4"
	NI-80	28'-9"	26'-8"	25'-5"	24'-1"	29'-5"	27'-5"	26'-2"	24'-6"
16"	NI-90	29'-4"	27'-2"	25'-11"	24'-6"	29'-11"	27'-11"	26'-7"	24'-9"
	NI-60	29'-7"	27'-6"	25'-9"	23'-0"	30'-4"	28'-3"	25'-9"	23'-0"
	NI-80	31'-7"	29'-4"	27'-11"	26'-5"	32'-5"	30'-1"	28'-9"	26'-10"
	NI-90	32'-3"	29'-10"	28'-5"	26'-10"	33'-2"	30'-7"	29'-2"	26'-10"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M4.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-11"	15'-0"	14'-6"	13'-5"	16'-5"	15'-5"	14'-6"	13'-5"
	NI-40x	17'-0"	16'-0"	15'-5"	14'-10"	17'-5"	16'-5"	15'-10"	14'-11"
	NI-60	17'-2"	16'-2"	15'-7"	14'-11"	17'-7"	16'-7"	16'-0"	15'-4"
	NI-80	18'-3"	17'-1"	16'-5"	15'-9"	18'-8"	17'-5"	16'-9"	16'-1"
11-7/8"	NI-20	17'-11"	16'-11"	16'-3"	15'-8"	18'-7"	17'-5"	16'-10"	16'-1"
	NI-40x	19'-4"	17'-11"	17'-3"	16'-7"	19'-11"	18'-6"	17'-9"	17'-0"
	NI-60	19'-7"	18'-2"	17'-6"	16'-9"	20'-2"	18'-9"	17'-11"	17'-2"
	NI-80	21'-1"	19'-6"	18'-6"	17'-7"	21'-7"	20'-0"	19'-0"	18'-0"
14"	NI-90	21'-6"	19'-10"	18'-11"	17'-11"	22'-0"	20'-4"	19'-5"	18'-4"
	NI-40x	21'-5"	19'-11"	18'-11"	18'-0"	22'-1"	20'-7"	19'-7"	18'-7"
	NI-60	21'-10"	20'-2"	19'-3"	18'-3"	22'-6"	20'-10"	19'-11"	18'-10"
	NI-80	23'-5"	21'-7"	20'-7"	19'-5"	24'-0"	22'-3"	21'-2"	20'-0"
16"	NI-90	23'-10"	22'-1"	21'-0"	19'-10"	24'-5"	22'-7"	21'-6"	20'-4"
	NI-60	23'-9"	22'-0"	21'-0"	19'-10"	24'-6"	22'-9"	21'-8"	20'-7"
	NI-80	25'-6"	23'-7"	22'-5"	21'-2"	26'-2"	24'-3"	23'-1"	21'-10"
	NI-90	26'-0"	24'-0"	22'-10"	21'-6"	26'-7"	24'-8"	23'-5"	22'-2"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-6"	13'-5"	16'-10"	15'-5"	14'-6"	13'-5"
	NI-40x	18'-8"	17'-2"	16'-3"	14'-11"	18'-10"	17'-2"	16'-3"	14'-11"
	NI-60	18'-11"	17'-6"	16'-6"	15'-5"	19'-2"	17'-6"	16'-6"	15'-5"
	NI-80	20'-3"	18'-10"	17'-11"	16'-10"	20'-8"	19'-3"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-1"	20'-1"	18'-5"	17'-5"	16'-1"
	NI-40x	21'-10"	20'-4"	19'-0"	17'-0"	22'-5"	20'-6"	19'-0"	17'-0"
	NI-60	22'-1"	20'-7"	19'-8"	18'-4"	22'-8"	20'-10"	19'-8"	18'-4"
	NI-80	23'-8"	22'-0"	20'-11"	19'-10"	24'-1"	22'-6"	21'-6"	20'-0"
14"	NI-90	24'-1"	22'-5"	21'-4"	20'-2"	24'-7"	22'-11"	21'-10"	20'-7"
	NI-40x	24'-5"	22'-9"	20'-11"	18'-8"	25'-1"	22'-11"	20'-11"	18'-8"
	NI-60	24'-10"	23'-2"	22'-1"	20'-10"	25'-6"	23'-8"	22'-4"	20'-10"
	NI-80	26'-6"	24'-8"	23'-6"	22'-2"	27'-1"	25'-3"	24'-1"	22'-9"
16"	NI-90	27'-0"	25'-1"	23'-11"	22'-7"	27'-6"	25'-8"	24'-6"	23'-2"
	NI-60	27'-3"	25'-5"	24'-3"	22'-11"	28'-0"	26'-2"	24'-9"	23'-1"
	NI-80	29'-1"	27'-1"	25'-9"	24'-4"	29'-8"	27'-9"	26'-5"	25'-0"
	NI-90	29'-7"	27'-6"	26'-2"	24'-9"	30'-2"	28'-2"	26'-10"	25'-5"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M4.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-2"	16'-2"	15'-8"	14'-0"	17'-8"	16'-9"	15'-8"	14'-0"
	NI-40x	18'-5"	17'-3"	16'-8"	14'-10"	19'-0"	17'-9"	16'-8"	14'-10"
	NI-60	18'-8"	17'-5"	16'-10"	16'-1"	19'-3"	17'-11"	17'-3"	16'-6"
	NI-80	20'-1"	18'-7"	17'-9"	17'-0"	20'-7"	19'-1"	18'-3"	17'-5"
11-7/8"	NI-20	19'-8"	18'-3"	17'-7"	16'-0"	20'-6"	19'-1"	17'-11"	16'-0"
	NI-40x	21'-4"	19'-9"	18'-10"	16'-11"	22'-0"	20'-6"	19'-0"	16'-11"
	NI-60	21'-8"	20'-1"	19'-1"	18'-1"	22'-3"	20'-9"	19'-9"	18'-9"
	NI-80	23'-3"	21'-6"	20'-5"	19'-4"	23'-10"	22'-1"	21'-1"	19'-11"
	NI-90	23'-9"	21'-11"	20'-10"	19'-9"	24'-4"	22'-6"	21'-5"	20'-4"
14"	NI-40x	23'-8"	21'-11"	20'-10"	18'-7"	24'-5"	22'-9"	20'-10"	18'-7"
	NI-60	24'-1"	22'-3"	21'-3"	20'-1"	24'-10"	23'-1"	22'-0"	20'-10"
	NI-80	25'-10"	23'-10"	22'-9"	21'-6"	26'-6"	24'-7"	23'-5"	22'-2"
	NI-90	26'-4"	24'-4"	23'-2"	21'-11"	27'-0"	25'-0"	23'-10"	22'-6"
16"	NI-60	26'-3"	24'-3"	23'-2"	21'-11"	27'-1"	25'-2"	24'-0"	22'-9"
	NI-80	28'-2"	26'-0"	24'-9"	23'-5"	28'-10"	26'-9"	25'-6"	24'-2"
	NI-90	28'-8"	26'-6"	25'-2"	23'-10"	29'-5"	27'-3"	25'-11"	24'-6"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-4"	16'-9"	15'-8"	14'-0"	18'-4"	16'-9"	15'-8"	14'-0"
	NI-40x	20'-5"	18'-3"	16'-8"	14'-10"	20'-6"	18'-3"	16'-8"	14'-10"
	NI-60	20'-8"	19'-0"	18'-0"	16'-9"	20'-10"	19'-0"	18'-0"	16'-9"
	NI-80	22'-2"	20'-7"	19'-8"	17'-7"	22'-8"	20'-11"	19'-9"	17'-7"
11-7/8"	NI-20	21'-11"	19'-8"	17'-11"	16'-0"	21'-11"	19'-8"	17'-11"	16'-0"
	NI-40x	23'-10"	20'-10"	19'-0"	16'-11"	24'-1"	20'-10"	19'-0"	16'-11"
	NI-60	24'-2"	22'-6"	21'-5"	19'-5"	24'-10"	22'-8"	21'-5"	19'-5"
	NI-80	25'-10"	24'-1"	22'-11"	21'-8"	26'-5"	24'-8"	23'-5"	21'-9"
	NI-90	26'-4"	24'-6"	23'-4"	22'-1"	26'-11"	25'-1"	23'-11"	22'-4"
14"	NI-40x	26'-5"	22'-10"	20'-10"	18'-7"	26'-5"	22'-10"	20'-10"	18'-7"
	NI-60	27'-2"	25'-3"	23'-11"	21'-4"	27'-10"	25'-9"	23'-11"	21'-4"
	NI-80	29'-0"	27'-0"	25'-8"	24'-3"	29'-7"	27'-8"	26'-5"	24'-6"
	NI-90	29'-7"	27'-6"	26'-2"	24'-9"	30'-2"	28'-2"	26'-10"	24'-9"
16"	NI-60	29'-10"	27'-9"	25'-9"	23'-0"	30'-7"	28'-3"	25'-9"	23'-0"
	NI-80	31'-10"	29'-7"	28'-2"	26'-7"	32'-9"	30'-4"	29'-0"	26'-10"
	NI-90	32'-7"	30'-1"	28'-8"	26'-10"	33'-6"	30'-10"	29'-5"	26'-10"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M5.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-5"	14'-6"	13'-5"	17'-0"	15'-5"	14'-6"	13'-5"
	NI-40x	17'-9"	16'-9"	16'-2"	14'-11"	18'-2"	17'-2"	16'-5"	14'-11"
	NI-60	17'-11"	16'-11"	16'-3"	15'-6"	18'-5"	17'-3"	16'-8"	15'-6"
	NI-80	19'-3"	17'-10"	17'-2"	16'-5"	19'-8"	18'-3"	17'-6"	16'-9"
11-7/8"	NI-20	18'-11"	17'-8"	17'-0"	16'-1"	19'-7"	18'-3"	17'-6"	16'-1"
	NI-40x	20'-5"	19'-0"	18'-1"	17'-0"	21'-0"	19'-7"	18'-8"	17'-0"
	NI-60	20'-8"	19'-3"	18'-4"	17'-5"	21'-3"	19'-10"	18'-11"	17'-10"
	NI-80	22'-2"	20'-7"	19'-7"	18'-5"	22'-8"	21'-1"	20'-1"	18'-11"
14"	NI-90	22'-8"	21'-0"	19'-11"	18'-9"	23'-2"	21'-6"	20'-5"	19'-3"
	NI-40x	22'-7"	21'-0"	20'-0"	18'-8"	23'-3"	21'-8"	20'-8"	18'-8"
	NI-60	23'-0"	21'-4"	20'-4"	19'-2"	23'-8"	22'-0"	21'-0"	19'-10"
	NI-80	24'-8"	22'-10"	21'-8"	20'-5"	25'-3"	23'-5"	22'-4"	21'-0"
16"	NI-90	25'-2"	23'-3"	22'-1"	20'-10"	25'-8"	23'-10"	22'-8"	21'-5"
	NI-60	25'-1"	23'-3"	22'-1"	20'-10"	25'-9"	24'-0"	22'-11"	21'-7"
	NI-80	26'-10"	24'-10"	23'-7"	22'-3"	27'-6"	25'-6"	24'-3"	22'-11"
	NI-90	27'-4"	25'-4"	24'-1"	22'-7"	27'-11"	25'-11"	24'-8"	23'-3"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-0"	15'-5"	14'-6"	13'-5"	17'-0"	15'-5"	14'-6"	13'-5"
	NI-40x	19'-0"	17'-4"	16'-5"	14'-11"	19'-0"	17'-4"	16'-5"	14'-11"
	NI-60	19'-3"	17'-8"	16'-8"	15'-6"	19'-3"	17'-8"	16'-8"	15'-6"
	NI-80	20'-11"	19'-5"	18'-3"	17'-0"	21'-3"	19'-5"	18'-3"	17'-0"
11-7/8"	NI-20	20'-4"	18'-7"	17'-6"	16'-1"	20'-4"	18'-7"	17'-6"	16'-1"
	NI-40x	22'-7"	20'-8"	19'-0"	17'-0"	22'-7"	20'-8"	19'-0"	17'-0"
	NI-60	22'-10"	21'-0"	19'-10"	18'-6"	23'-0"	21'-0"	19'-10"	18'-6"
	NI-80	24'-5"	22'-9"	21'-8"	20'-2"	24'-11"	23'-0"	21'-8"	20'-2"
14"	NI-90	24'-11"	23'-3"	22'-2"	20'-9"	25'-4"	23'-8"	22'-3"	20'-9"
	NI-40x	25'-2"	22'-11"	20'-11"	18'-8"	25'-6"	22'-11"	20'-11"	18'-8"
	NI-60	25'-7"	23'-10"	22'-6"	21'-0"	26'-1"	23'-10"	22'-6"	21'-0"
	NI-80	27'-4"	25'-6"	24'-4"	22'-11"	27'-10"	26'-1"	24'-7"	22'-11"
16"	NI-90	27'-10"	26'-0"	24'-9"	23'-4"	28'-4"	26'-7"	25'-3"	23'-6"
	NI-60	28'-1"	26'-3"	24'-11"	23'-1"	28'-9"	26'-5"	24'-11"	23'-1"
	NI-80	29'-11"	27'-11"	26'-8"	25'-1"	30'-6"	28'-7"	27'-3"	25'-4"
	NI-90	30'-6"	28'-5"	27'-1"	25'-6"	31'-0"	29'-1"	27'-9"	25'-11"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M5.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	16'-10"	15'-8"	14'-0"	18'-6"	16'-10"	15'-8"	14'-0"
	NI-40x	19'-6"	18'-1"	16'-8"	14'-10"	20'-1"	18'-3"	16'-8"	14'-10"
	NI-60	19'-9"	18'-4"	17'-7"	16'-9"	20'-3"	18'-11"	18'-0"	16'-10"
	NI-80	21'-3"	19'-8"	18'-9"	17'-7"	21'-8"	20'-2"	19'-3"	17'-7"
11-7/8"	NI-20	20'-9"	19'-4"	17'-11"	16'-0"	21'-7"	19'-8"	17'-11"	16'-0"
	NI-40x	22'-6"	20'-10"	19'-0"	16'-11"	23'-2"	20'-10"	19'-0"	16'-11"
	NI-60	22'-10"	21'-2"	20'-2"	19'-0"	23'-6"	21'-10"	20'-10"	19'-5"
	NI-80	24'-6"	22'-8"	21'-7"	20'-4"	25'-1"	23'-3"	22'-2"	20'-11"
	NI-90	25'-0"	23'-2"	22'-0"	20'-9"	25'-7"	23'-9"	22'-7"	21'-4"
14"	NI-40x	24'-11"	22'-10"	20'-10"	18'-7"	25'-8"	22'-10"	20'-10"	18'-7"
	NI-60	25'-4"	23'-6"	22'-5"	21'-1"	26'-1"	24'-4"	23'-2"	21'-4"
	NI-80	27'-2"	25'-2"	24'-0"	22'-7"	27'-10"	25'-11"	24'-8"	23'-3"
	NI-90	27'-9"	25'-8"	24'-5"	23'-0"	28'-4"	26'-4"	25'-1"	23'-8"
16"	NI-60	27'-7"	25'-8"	24'-5"	23'-0"	28'-5"	26'-6"	25'-3"	23'-0"
	NI-80	29'-7"	27'-5"	26'-1"	24'-7"	30'-4"	28'-2"	26'-10"	25'-4"
	NI-90	30'-2"	27'-11"	26'-7"	25'-0"	30'-10"	28'-8"	27'-4"	25'-9"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-6"	16'-10"	15'-8"	14'-0"	18'-6"	16'-10"	15'-8"	14'-0"
	NI-40x	20'-8"	18'-3"	16'-8"	14'-10"	20'-8"	18'-3"	16'-8"	14'-10"
	NI-60	21'-0"	19'-2"	18'-1"	16'-10"	21'-0"	19'-2"	18'-1"	16'-10"
	NI-80	22'-11"	21'-1"	19'-11"	17'-7"	23'-1"	21'-1"	19'-11"	17'-7"
11-7/8"	NI-20	22'-1"	19'-8"	17'-11"	16'-0"	22'-1"	19'-8"	17'-11"	16'-0"
	NI-40x	24'-1"	20'-10"	19'-0"	16'-11"	24'-1"	20'-10"	19'-0"	16'-11"
	NI-60	25'-0"	22'-11"	21'-7"	19'-5"	25'-1"	22'-11"	21'-7"	19'-5"
	NI-80	26'-9"	24'-11"	23'-7"	21'-10"	27'-3"	25'-1"	23'-7"	21'-10"
	NI-90	27'-3"	25'-5"	24'-3"	22'-6"	27'-10"	25'-9"	24'-3"	22'-6"
14"	NI-40x	26'-5"	22'-10"	20'-10"	18'-7"	26'-5"	22'-10"	20'-10"	18'-7"
	NI-60	28'-0"	26'-0"	23'-11"	21'-4"	28'-5"	26'-0"	23'-11"	21'-4"
	NI-80	29'-11"	27'-11"	26'-7"	24'-6"	30'-6"	28'-5"	26'-9"	24'-6"
	NI-90	30'-6"	28'-5"	27'-1"	24'-9"	31'-1"	29'-1"	27'-6"	24'-9"
16"	NI-60	30'-8"	28'-3"	25'-9"	23'-0"	31'-6"	28'-3"	25'-9"	23'-0"
	NI-80	33'-1"	30'-7"	29'-2"	26'-10"	34'-0"	31'-4"	29'-8"	26'-10"
	NI-90	33'-11"	31'-2"	29'-8"	26'-10"	34'-10"	31'-11"	30'-5"	26'-10"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M6.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-1"	-
	NI-80	17'-1"	16'-1"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-4"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-6"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-9"	17'-6"	16'-11"	-
	NI-80	19'-6"	18'-0"	17'-4"	-	20'-1"	18'-7"	17'-9"	-
	NI-90	19'-11"	18'-4"	17'-8"	-	20'-5"	18'-11"	18'-1"	-
14"	NI-40x	19'-10"	18'-4"	17'-8"	-	20'-6"	19'-1"	18'-3"	-
	NI-60	20'-2"	18'-8"	17'-11"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-8"	20'-0"	19'-1"	-	22'-4"	20'-8"	19'-9"	-
	NI-90	22'-1"	20'-5"	19'-6"	-	22'-9"	21'-0"	20'-1"	-
16"	NI-60	22'-0"	20'-4"	19'-6"	-	22'-9"	21'-1"	20'-2"	-
	NI-80	23'-7"	21'-10"	20'-10"	-	24'-4"	22'-6"	21'-6"	-
	NI-90	24'-1"	22'-2"	21'-2"	-	24'-9"	22'-11"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-6"	15'-1"	14'-3"	-	16'-6"	15'-1"	14'-3"	-
	NI-40x	17'-9"	16'-10"	15'-11"	-	18'-2"	16'-11"	15'-11"	-
	NI-60	17'-11"	16'-11"	16'-2"	-	18'-5"	17'-2"	16'-2"	-
	NI-80	19'-3"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	18'-0"	17'-1"	-	19'-9"	18'-1"	17'-1"	-
	NI-40x	20'-10"	19'-4"	18'-6"	-	21'-5"	19'-11"	19'-0"	-
	NI-60	21'-1"	19'-7"	18'-8"	-	21'-8"	20'-2"	19'-3"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
14"	NI-40x	23'-5"	21'-8"	20'-9"	-	24'-0"	22'-5"	20'-11"	-
	NI-60	23'-9"	22'-0"	21'-0"	-	24'-5"	22'-8"	21'-8"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
	NI-90	25'-10"	23'-11"	22'-9"	-	26'-5"	24'-6"	23'-4"	-
16"	NI-60	26'-2"	24'-3"	23'-2"	-	26'-11"	25'-0"	23'-11"	-
	NI-80	27'-11"	25'-10"	24'-7"	-	28'-7"	26'-6"	25'-3"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M6.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-8"	-	16'-7"	15'-8"	15'-2"	-
	NI-40x	17'-2"	16'-2"	15'-8"	-	17'-8"	16'-8"	16'-1"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-7"	17'-4"	16'-9"	-	19'-2"	17'-9"	17'-2"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-6"	-	18'-11"	17'-8"	17'-1"	-
	NI-40x	19'-8"	18'-3"	17'-7"	-	20'-5"	18'-11"	18'-2"	-
	NI-60	20'-0"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-5"	-
	NI-80	21'-6"	19'-11"	19'-0"	-	22'-2"	20'-6"	19'-7"	-
	NI-90	22'-0"	20'-4"	19'-5"	-	22'-7"	20'-11"	20'-0"	-
14"	NI-40x	21'-10"	20'-3"	19'-5"	-	22'-8"	21'-1"	20'-2"	-
	NI-60	22'-3"	20'-7"	19'-9"	-	23'-0"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-10"	-
	NI-90	24'-5"	22'-7"	21'-6"	-	25'-2"	23'-3"	22'-3"	-
16"	NI-60	24'-3"	22'-6"	21'-6"	-	25'-2"	23'-4"	22'-4"	-
	NI-80	26'-1"	24'-1"	23'-0"	-	26'-11"	24'-11"	23'-9"	-
	NI-90	26'-7"	24'-7"	23'-5"	-	27'-5"	25'-4"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-10"	16'-5"	15'-6"	-	17'-11"	16'-5"	15'-6"	-
	NI-40x	19'-4"	18'-0"	16'-8"	-	19'-11"	18'-3"	16'-8"	-
	NI-60	19'-7"	18'-2"	17'-6"	-	20'-2"	18'-8"	17'-7"	-
	NI-80	21'-0"	19'-6"	18'-8"	-	21'-6"	20'-0"	19'-1"	-
11-7/8"	NI-20	21'-0"	19'-7"	17'-11"	-	21'-6"	19'-8"	17'-11"	-
	NI-40x	22'-8"	20'-10"	19'-0"	-	23'-5"	20'-10"	19'-0"	-
	NI-60	23'-0"	21'-4"	20'-5"	-	23'-8"	22'-1"	21'-0"	-
	NI-80	24'-8"	22'-10"	21'-9"	-	25'-3"	23'-5"	22'-5"	-
	NI-90	25'-2"	23'-3"	22'-3"	-	25'-9"	23'-11"	22'-10"	-
14"	NI-40x	25'-6"	22'-10"	20'-10"	-	26'-3"	22'-10"	20'-10"	-
	NI-60	25'-11"	24'-0"	22'-11"	-	26'-8"	24'-10"	23'-9"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-7"	-
16"	NI-60	28'-7"	26'-6"	25'-3"	-	29'-4"	27'-4"	25'-9"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-2"	29'-0"	27'-8"	-
	NI-90	31'-1"	28'-9"	27'-4"	-	31'-9"	29'-6"	28'-2"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M7.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-10"	15'-0"	14'-5"	13'-5"	16'-4"	15'-5"	14'-6"	13'-5"
	NI-40x	16'-11"	15'-11"	15'-4"	14'-9"	17'-4"	16'-4"	15'-9"	14'-11"
	NI-60	17'-1"	16'-1"	15'-6"	14'-10"	17'-6"	16'-6"	15'-11"	15'-3"
	NI-80	18'-1"	17'-0"	16'-4"	15'-8"	18'-7"	17'-4"	16'-8"	16'-0"
11-7/8"	NI-20	17'-10"	16'-10"	16'-2"	15'-7"	18'-5"	17'-4"	16'-9"	16'-1"
	NI-40x	19'-3"	17'-10"	17'-2"	16'-6"	19'-10"	18'-5"	17'-8"	16'-11"
	NI-60	19'-6"	18'-1"	17'-4"	16'-8"	20'-1"	18'-8"	17'-10"	17'-1"
	NI-80	20'-11"	19'-4"	18'-5"	17'-7"	21'-5"	19'-10"	18'-11"	17'-11"
	NI-90	21'-4"	19'-9"	18'-9"	17'-10"	21'-10"	20'-3"	19'-3"	18'-3"
14"	NI-40x	21'-4"	19'-9"	18'-10"	17'-11"	22'-0"	20'-5"	19'-6"	18'-6"
	NI-60	21'-8"	20'-1"	19'-2"	18'-2"	22'-4"	20'-9"	19'-9"	18'-9"
	NI-80	23'-3"	21'-6"	20'-5"	19'-4"	23'-10"	22'-1"	21'-0"	19'-11"
	NI-90	23'-9"	21'-11"	20'-10"	19'-8"	24'-3"	22'-6"	21'-5"	20'-3"
16"	NI-60	23'-7"	21'-10"	20'-10"	19'-9"	24'-4"	22'-7"	21'-7"	20'-5"
	NI-80	25'-4"	23'-5"	22'-3"	21'-1"	26'-0"	24'-1"	22'-11"	21'-8"
	NI-90	25'-10"	23'-10"	22'-8"	21'-5"	26'-5"	24'-6"	23'-4"	22'-0"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-6"	13'-5"	16'-10"	15'-5"	14'-6"	13'-5"
	NI-40x	18'-7"	17'-2"	16'-3"	14'-11"	18'-10"	17'-2"	16'-3"	14'-11"
	NI-60	18'-10"	17'-6"	16'-6"	15'-5"	19'-1"	17'-6"	16'-6"	15'-5"
	NI-80	20'-2"	18'-9"	17'-11"	16'-10"	20'-7"	19'-2"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	18'-5"	17'-5"	16'-1"	20'-1"	18'-5"	17'-5"	16'-1"
	NI-40x	21'-9"	20'-3"	19'-0"	17'-0"	22'-4"	20'-5"	19'-0"	17'-0"
	NI-60	22'-0"	20'-6"	19'-7"	18'-4"	22'-7"	20'-10"	19'-8"	18'-4"
	NI-80	23'-6"	21'-10"	20'-10"	19'-9"	24'-0"	22'-5"	21'-4"	20'-0"
	NI-90	24'-0"	22'-4"	21'-3"	20'-1"	24'-6"	22'-10"	21'-9"	20'-7"
14"	NI-40x	24'-4"	22'-8"	20'-11"	18'-8"	25'-0"	22'-11"	20'-11"	18'-8"
	NI-60	24'-9"	23'-0"	22'-0"	20'-9"	25'-5"	23'-8"	22'-4"	20'-10"
	NI-80	26'-5"	24'-6"	23'-4"	22'-1"	27'-0"	25'-2"	24'-0"	22'-8"
	NI-90	26'-11"	25'-0"	23'-10"	22'-6"	27'-5"	25'-7"	24'-5"	23'-1"
16"	NI-60	27'-2"	25'-4"	24'-2"	22'-10"	27'-11"	26'-1"	24'-9"	23'-1"
	NI-80	29'-0"	26'-11"	25'-8"	24'-3"	29'-7"	27'-7"	26'-4"	24'-11"
	NI-90	29'-6"	27'-5"	26'-1"	24'-8"	30'-1"	28'-1"	26'-9"	25'-4"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – M7.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 20 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-1"	16'-1"	15'-7"	14'-0"	17'-7"	16'-8"	15'-8"	14'-0"
	NI-40x	18'-4"	17'-2"	16'-7"	14'-10"	18'-11"	17'-8"	16'-8"	14'-10"
	NI-60	18'-7"	17'-4"	16'-9"	16'-1"	19'-1"	17'-9"	17'-2"	16'-6"
	NI-80	20'-0"	18'-6"	17'-8"	16'-11"	20'-6"	19'-0"	18'-1"	17'-4"
11-7/8"	NI-20	19'-7"	18'-2"	17'-6"	16'-0"	20'-4"	18'-11"	17'-11"	16'-0"
	NI-40x	21'-2"	19'-8"	18'-9"	16'-11"	21'-10"	20'-4"	19'-0"	16'-11"
	NI-60	21'-6"	19'-11"	19'-0"	18'-0"	22'-2"	20'-7"	19'-8"	18'-8"
	NI-80	23'-1"	21'-4"	20'-4"	19'-3"	23'-8"	21'-11"	20'-11"	19'-10"
14"	NI-90	23'-7"	21'-9"	20'-9"	19'-8"	24'-2"	22'-5"	21'-4"	20'-2"
	NI-40x	23'-6"	21'-9"	20'-9"	18'-7"	24'-3"	22'-7"	20'-10"	18'-7"
	NI-60	23'-11"	22'-2"	21'-1"	20'-0"	24'-8"	22'-11"	21'-10"	20'-9"
	NI-80	25'-8"	23'-9"	22'-7"	21'-4"	26'-4"	24'-5"	23'-3"	22'-0"
16"	NI-90	26'-2"	24'-2"	23'-0"	21'-9"	26'-10"	24'-10"	23'-8"	22'-5"
	NI-60	26'-1"	24'-1"	23'-0"	21'-9"	26'-11"	25'-0"	23'-10"	22'-7"
	NI-80	27'-11"	25'-10"	24'-7"	23'-3"	28'-8"	26'-7"	25'-4"	24'-0"
NI-90	28'-6"	26'-4"	25'-0"	23'-8"	29'-3"	27'-1"	25'-9"	24'-5"	

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-4"	16'-9"	15'-8"	14'-0"	18'-4"	16'-9"	15'-8"	14'-0"
	NI-40x	20'-4"	18'-3"	16'-8"	14'-10"	20'-6"	18'-3"	16'-8"	14'-10"
	NI-60	20'-7"	19'-0"	17'-11"	16'-9"	20'-10"	19'-0"	17'-11"	16'-9"
	NI-80	22'-1"	20'-6"	19'-7"	17'-7"	22'-7"	20'-11"	19'-9"	17'-7"
11-7/8"	NI-20	21'-11"	19'-8"	17'-11"	16'-0"	21'-11"	19'-8"	17'-11"	16'-0"
	NI-40x	23'-9"	20'-10"	19'-0"	16'-11"	24'-1"	20'-10"	19'-0"	16'-11"
	NI-60	24'-1"	22'-5"	21'-5"	19'-5"	24'-9"	22'-8"	21'-5"	19'-5"
	NI-80	25'-9"	23'-11"	22'-10"	21'-7"	26'-4"	24'-7"	23'-5"	21'-9"
14"	NI-90	26'-3"	24'-5"	23'-3"	22'-0"	26'-10"	25'-0"	23'-10"	22'-4"
	NI-40x	26'-5"	22'-10"	20'-10"	18'-7"	26'-5"	22'-10"	20'-10"	18'-7"
	NI-60	27'-0"	25'-2"	23'-11"	21'-4"	27'-9"	25'-9"	23'-11"	21'-4"
	NI-80	28'-11"	26'-10"	25'-7"	24'-2"	29'-6"	27'-7"	26'-4"	24'-6"
16"	NI-90	29'-5"	27'-4"	26'-1"	24'-7"	30'-1"	28'-0"	26'-9"	24'-9"
	NI-60	29'-8"	27'-8"	25'-9"	23'-0"	30'-6"	28'-3"	25'-9"	23'-0"
	NI-80	31'-8"	29'-6"	28'-1"	26'-6"	32'-7"	30'-3"	28'-10"	26'-10"
NI-90	32'-5"	30'-0"	28'-7"	26'-10"	33'-4"	30'-9"	29'-4"	26'-10"	

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H1.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-0"	-
	NI-80	17'-0"	16'-0"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-3"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-5"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-8"	17'-6"	16'-11"	-
	NI-80	19'-5"	17'-11"	17'-4"	-	20'-0"	18'-6"	17'-9"	-
	NI-90	19'-10"	18'-4"	17'-7"	-	20'-5"	18'-10"	18'-0"	-
14"	NI-40x	19'-9"	18'-4"	17'-8"	-	20'-6"	19'-0"	18'-3"	-
	NI-60	20'-1"	18'-7"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-7"	19'-11"	19'-1"	-	22'-3"	20'-7"	19'-8"	-
	NI-90	22'-0"	20'-4"	19'-5"	-	22'-8"	21'-0"	20'-0"	-
16"	NI-60	21'-11"	20'-4"	19'-5"	-	22'-8"	21'-1"	20'-2"	-
	NI-80	23'-6"	21'-9"	20'-9"	-	24'-3"	22'-5"	21'-5"	-
	NI-90	23'-11"	22'-1"	21'-2"	-	24'-8"	22'-10"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-7"	15'-2"	14'-3"	-	16'-7"	15'-2"	14'-3"	-
	NI-40x	17'-9"	16'-7"	15'-1"	-	18'-3"	16'-7"	15'-1"	-
	NI-60	17'-11"	16'-11"	16'-4"	-	18'-5"	17'-3"	16'-4"	-
	NI-80	19'-2"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	17'-10"	16'-3"	-	19'-11"	17'-10"	16'-3"	-
	NI-40x	20'-10"	18'-10"	17'-3"	-	21'-5"	18'-10"	17'-3"	-
	NI-60	21'-1"	19'-7"	18'-9"	-	21'-8"	20'-2"	19'-4"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
14"	NI-40x	23'-5"	20'-9"	18'-11"	-	24'-0"	20'-9"	18'-11"	-
	NI-60	23'-9"	22'-1"	21'-1"	-	24'-5"	22'-9"	21'-8"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
	NI-90	25'-10"	23'-11"	22'-10"	-	26'-5"	24'-6"	23'-5"	-
16"	NI-60	26'-3"	24'-3"	23'-2"	-	26'-11"	25'-1"	23'-4"	-
	NI-80	27'-11"	25'-10"	24'-8"	-	28'-7"	26'-6"	25'-4"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H1.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	19/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-2"	-	16'-7"	15'-7"	14'-2"	-
	NI-40x	17'-2"	16'-2"	15'-0"	-	17'-8"	16'-6"	15'-0"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-6"	17'-4"	16'-9"	-	19'-1"	17'-9"	17'-1"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-2"	-	18'-11"	17'-8"	16'-2"	-
	NI-40x	19'-8"	18'-3"	17'-2"	-	20'-4"	18'-10"	17'-2"	-
	NI-60	19'-11"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-4"	-
	NI-80	21'-5"	19'-10"	19'-0"	-	22'-1"	20'-6"	19'-7"	-
14"	NI-90	21'-11"	20'-3"	19'-4"	-	22'-6"	20'-10"	19'-11"	-
	NI-40x	21'-9"	20'-3"	18'-10"	-	22'-7"	20'-8"	18'-10"	-
	NI-60	22'-2"	20'-7"	19'-8"	-	23'-0"	21'-4"	20'-5"	-
	NI-80	23'-10"	22'-0"	21'-1"	-	24'-7"	22'-9"	21'-9"	-
16"	NI-90	24'-4"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-
	NI-60	24'-2"	22'-5"	21'-5"	-	25'-1"	23'-4"	22'-4"	-
	NI-80	26'-0"	24'-0"	22'-11"	-	26'-10"	24'-10"	23'-9"	-
	NI-90	26'-6"	24'-5"	23'-4"	-	27'-4"	25'-3"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	15'-7"	14'-2"	-	18'-0"	15'-7"	14'-2"	-
	NI-40x	19'-1"	16'-6"	15'-0"	-	19'-1"	16'-6"	15'-0"	-
	NI-60	19'-7"	18'-2"	17'-3"	-	20'-2"	18'-9"	17'-3"	-
	NI-80	21'-0"	19'-6"	18'-0"	-	21'-6"	20'-0"	18'-0"	-
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	-	20'-6"	17'-9"	16'-2"	-
	NI-40x	21'-9"	18'-10"	17'-2"	-	21'-9"	18'-10"	17'-2"	-
	NI-60	23'-0"	21'-4"	19'-8"	-	23'-8"	21'-7"	19'-8"	-
	NI-80	24'-7"	22'-10"	21'-10"	-	25'-3"	23'-5"	22'-4"	-
14"	NI-90	25'-1"	23'-3"	22'-3"	-	25'-9"	23'-10"	22'-10"	-
	NI-40x	23'-11"	20'-8"	18'-10"	-	23'-11"	20'-8"	18'-10"	-
	NI-60	25'-11"	23'-8"	21'-7"	-	26'-8"	23'-8"	21'-7"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
16"	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-4"	-
	NI-60	28'-7"	25'-6"	23'-4"	-	29'-5"	25'-6"	23'-4"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-3"	29'-0"	27'-6"	-
	NI-90	31'-0"	28'-9"	27'-4"	-	31'-9"	29'-6"	27'-6"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H2.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-1"	14'-3"	13'-10"	-	15'-7"	14'-9"	14'-3"	-
	NI-40x	16'-2"	15'-3"	14'-8"	-	16'-7"	15'-8"	15'-1"	-
	NI-60	16'-4"	15'-4"	14'-10"	-	16'-9"	15'-9"	15'-3"	-
	NI-80	17'-3"	16'-3"	15'-8"	-	17'-8"	16'-7"	16'-0"	-
11-7/8"	NI-20	17'-0"	16'-0"	15'-6"	-	17'-6"	16'-7"	16'-0"	-
	NI-40x	18'-2"	17'-1"	16'-6"	-	18'-9"	17'-6"	16'-11"	-
	NI-60	18'-5"	17'-3"	16'-8"	-	19'-0"	17'-8"	17'-1"	-
	NI-80	19'-9"	18'-3"	17'-7"	-	20'-4"	18'-10"	18'-0"	-
	NI-90	20'-2"	18'-8"	17'-10"	-	20'-9"	19'-2"	18'-4"	-
14"	NI-40x	20'-1"	18'-8"	17'-10"	-	20'-10"	19'-4"	18'-6"	-
	NI-60	20'-6"	18'-11"	18'-2"	-	21'-2"	19'-8"	18'-9"	-
	NI-80	21'-11"	20'-3"	19'-4"	-	22'-7"	20'-11"	20'-0"	-
	NI-90	22'-5"	20'-8"	19'-9"	-	23'-0"	21'-4"	20'-4"	-
16"	NI-60	22'-4"	20'-8"	19'-9"	-	23'-1"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-9"	-
	NI-90	24'-5"	22'-6"	21'-6"	-	25'-1"	23'-2"	22'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-3"	14'-3"	-	16'-8"	15'-3"	14'-3"	-
	NI-40x	17'-11"	16'-7"	15'-1"	-	18'-5"	16'-7"	15'-1"	-
	NI-60	18'-2"	17'-1"	16'-4"	-	18'-8"	17'-4"	16'-4"	-
	NI-80	19'-5"	18'-0"	17'-5"	-	19'-10"	18'-5"	17'-8"	-
11-7/8"	NI-20	19'-7"	17'-10"	16'-3"	-	19'-11"	17'-10"	16'-3"	-
	NI-40x	21'-1"	18'-10"	17'-3"	-	21'-8"	18'-10"	17'-3"	-
	NI-60	21'-4"	19'-9"	18'-11"	-	21'-11"	20'-5"	19'-6"	-
	NI-80	22'-9"	21'-1"	20'-2"	-	23'-3"	21'-8"	20'-8"	-
	NI-90	23'-3"	21'-6"	20'-6"	-	23'-9"	22'-0"	21'-0"	-
14"	NI-40x	23'-8"	20'-9"	18'-11"	-	24'-0"	20'-9"	18'-11"	-
	NI-60	24'-0"	22'-3"	21'-3"	-	24'-8"	22'-11"	21'-8"	-
	NI-80	25'-7"	23'-9"	22'-7"	-	26'-2"	24'-4"	23'-3"	-
	NI-90	26'-1"	24'-2"	23'-0"	-	26'-8"	24'-9"	23'-7"	-
16"	NI-60	26'-5"	24'-6"	23'-4"	-	27'-2"	25'-3"	23'-4"	-
	NI-80	28'-2"	26'-1"	24'-10"	-	28'-10"	26'-9"	25'-6"	-
	NI-90	28'-8"	26'-6"	25'-3"	-	29'-3"	27'-2"	25'-11"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H2.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-3"	15'-4"	14'-2"	-	16'-10"	15'-7"	14'-2"	-
	NI-40x	17'-5"	16'-5"	15'-0"	-	17'-11"	16'-6"	15'-0"	-
	NI-60	17'-7"	16'-7"	16'-0"	-	18'-1"	17'-0"	16'-5"	-
	NI-80	18'-10"	17'-6"	16'-11"	-	19'-5"	18'-0"	17'-4"	-
11-7/8"	NI-20	18'-5"	17'-3"	16'-2"	-	19'-3"	17'-9"	16'-2"	-
	NI-40x	20'-0"	18'-7"	17'-2"	-	20'-8"	18'-10"	17'-2"	-
	NI-60	20'-3"	18'-10"	18'-0"	-	21'-0"	19'-6"	18'-8"	-
	NI-80	21'-10"	20'-2"	19'-3"	-	22'-5"	20'-10"	19'-10"	-
14"	NI-90	22'-3"	20'-7"	19'-8"	-	22'-11"	21'-2"	20'-3"	-
	NI-40x	22'-2"	20'-7"	18'-10"	-	23'-0"	20'-8"	18'-10"	-
	NI-60	22'-7"	20'-11"	20'-0"	-	23'-4"	21'-8"	20'-9"	-
	NI-80	24'-3"	22'-5"	21'-5"	-	25'-0"	23'-2"	22'-1"	-
16"	NI-90	24'-9"	22'-10"	21'-10"	-	25'-6"	23'-7"	22'-6"	-
	NI-60	24'-7"	22'-10"	21'-9"	-	25'-6"	23'-8"	22'-8"	-
	NI-80	26'-5"	24'-5"	23'-4"	-	27'-3"	25'-3"	24'-1"	-
	NI-90	26'-11"	24'-11"	23'-9"	-	27'-9"	25'-8"	24'-6"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-0"	15'-7"	14'-2"	-	18'-0"	15'-7"	14'-2"	-
	NI-40x	19'-1"	16'-6"	15'-0"	-	19'-1"	16'-6"	15'-0"	-
	NI-60	19'-10"	18'-5"	17'-3"	-	20'-5"	18'-10"	17'-3"	-
	NI-80	21'-3"	19'-8"	18'-0"	-	21'-9"	20'-3"	18'-0"	-
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	-	20'-6"	17'-9"	16'-2"	-
	NI-40x	21'-9"	18'-10"	17'-2"	-	21'-9"	18'-10"	17'-2"	-
	NI-60	23'-3"	21'-7"	19'-8"	-	23'-11"	21'-7"	19'-8"	-
	NI-80	24'-11"	23'-1"	22'-0"	-	25'-6"	23'-8"	22'-4"	-
14"	NI-90	25'-5"	23'-6"	22'-5"	-	26'-0"	24'-1"	23'-0"	-
	NI-40x	23'-11"	20'-8"	18'-10"	-	23'-11"	20'-8"	18'-10"	-
	NI-60	26'-2"	23'-8"	21'-7"	-	26'-11"	23'-8"	21'-7"	-
	NI-80	28'-0"	25'-11"	24'-9"	-	28'-8"	26'-8"	25'-2"	-
16"	NI-90	28'-6"	26'-5"	25'-2"	-	29'-2"	27'-1"	25'-4"	-
	NI-60	28'-10"	25'-6"	23'-4"	-	29'-6"	25'-6"	23'-4"	-
	NI-80	30'-9"	28'-6"	27'-2"	-	31'-6"	29'-3"	27'-6"	-
	NI-90	31'-4"	29'-0"	27'-6"	-	32'-1"	29'-9"	27'-6"	-

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H3.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-9"	14'-10"	14'-3"	12'-9"	16'-2"	15'-4"	14'-3"	12'-9"
	NI-40x	16'-10"	15'-10"	15'-1"	13'-6"	17'-2"	16'-3"	15'-1"	13'-6"
	NI-60	16'-11"	16'-0"	15'-5"	14'-9"	17'-4"	16'-4"	15'-9"	15'-2"
	NI-80	18'-0"	16'-11"	16'-3"	15'-7"	18'-5"	17'-3"	16'-7"	15'-11"
11-7/8"	NI-20	17'-8"	16'-8"	16'-1"	14'-6"	18'-3"	17'-3"	16'-3"	14'-6"
	NI-40x	19'-1"	17'-9"	17'-1"	15'-5"	19'-8"	18'-3"	17'-3"	15'-5"
	NI-60	19'-4"	17'-11"	17'-3"	16'-7"	19'-11"	18'-6"	17'-8"	17'-0"
	NI-80	20'-9"	19'-2"	18'-3"	17'-5"	21'-3"	19'-8"	18'-9"	17'-10"
14"	NI-90	21'-2"	19'-7"	18'-8"	17'-9"	21'-8"	20'-1"	19'-1"	18'-1"
	NI-40x	21'-2"	19'-7"	18'-8"	16'-11"	21'-10"	20'-3"	18'-11"	16'-11"
	NI-60	21'-6"	19'-11"	19'-0"	18'-0"	22'-2"	20'-7"	19'-8"	18'-8"
	NI-80	23'-1"	21'-4"	20'-3"	19'-3"	23'-8"	21'-11"	20'-10"	19'-9"
16"	NI-90	23'-6"	21'-9"	20'-8"	19'-7"	24'-1"	22'-4"	21'-3"	20'-1"
	NI-60	23'-5"	21'-8"	20'-8"	19'-7"	24'-2"	22'-5"	21'-5"	20'-4"
	NI-80	25'-1"	23'-2"	22'-1"	20'-11"	25'-9"	23'-10"	22'-9"	21'-6"
	NI-90	25'-7"	23'-7"	22'-6"	21'-3"	26'-3"	24'-3"	23'-1"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-9"	15'-4"	14'-3"	12'-9"	16'-9"	15'-4"	14'-3"	12'-9"
	NI-40x	18'-6"	16'-7"	15'-1"	13'-6"	18'-9"	16'-7"	15'-1"	13'-6"
	NI-60	18'-9"	17'-5"	16'-6"	15'-4"	19'-1"	17'-5"	16'-6"	15'-4"
	NI-80	20'-0"	18'-7"	17'-10"	16'-10"	20'-6"	19'-1"	18'-1"	16'-10"
11-7/8"	NI-20	20'-1"	17'-10"	16'-3"	14'-6"	20'-1"	17'-10"	16'-3"	14'-6"
	NI-40x	21'-8"	18'-10"	17'-3"	15'-5"	21'-10"	18'-10"	17'-3"	15'-5"
	NI-60	21'-11"	20'-5"	19'-6"	17'-8"	22'-6"	20'-10"	19'-8"	17'-8"
	NI-80	23'-5"	21'-9"	20'-9"	19'-8"	23'-11"	22'-3"	21'-3"	20'-0"
14"	NI-90	23'-11"	22'-2"	21'-1"	20'-0"	24'-4"	22'-8"	21'-8"	20'-6"
	NI-40x	24'-0"	20'-9"	18'-11"	16'-11"	24'-0"	20'-9"	18'-11"	16'-11"
	NI-60	24'-8"	22'-11"	21'-8"	19'-5"	25'-3"	23'-7"	21'-8"	19'-5"
	NI-80	26'-3"	24'-5"	23'-3"	22'-0"	26'-10"	25'-0"	23'-10"	22'-0"
16"	NI-90	26'-9"	24'-10"	23'-8"	22'-0"	27'-4"	25'-5"	24'-3"	22'-0"
	NI-60	27'-1"	25'-2"	23'-4"	20'-11"	27'-9"	25'-7"	23'-4"	20'-11"
	NI-80	28'-10"	26'-10"	25'-6"	23'-6"	29'-6"	27'-6"	26'-3"	23'-6"
	NI-90	29'-5"	27'-3"	26'-0"	23'-6"	30'-0"	27'-11"	26'-8"	23'-6"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H3.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	23/32 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-11"	15'-7"	14'-2"	12'-8"	17'-6"	15'-7"	14'-2"	12'-8"
	NI-40x	18'-2"	16'-6"	15'-0"	13'-5"	18'-9"	16'-6"	15'-0"	13'-5"
	NI-60	18'-5"	17'-3"	16'-7"	14'-4"	19'-0"	17'-8"	17'-1"	14'-4"
	NI-80	19'-10"	18'-4"	17'-7"	14'-4"	20'-4"	18'-10"	17'-11"	14'-4"
11-7/8"	NI-20	19'-5"	17'-9"	16'-2"	14'-5"	20'-2"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-0"	18'-10"	17'-2"	15'-4"	21'-8"	18'-10"	17'-2"	15'-4"
	NI-60	21'-4"	19'-9"	18'-10"	17'-7"	22'-0"	20'-5"	19'-6"	17'-7"
	NI-80	22'-11"	21'-2"	20'-2"	17'-10"	23'-6"	21'-9"	20'-9"	17'-10"
14"	NI-90	23'-5"	21'-7"	20'-7"	19'-6"	24'-0"	22'-2"	21'-2"	20'-0"
	NI-40x	23'-4"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	23'-8"	21'-11"	20'-11"	18'-11"	24'-5"	22'-9"	21'-7"	18'-11"
	NI-80	25'-5"	23'-6"	22'-5"	20'-1"	26'-2"	24'-3"	23'-1"	20'-1"
16"	NI-90	26'-0"	24'-0"	22'-10"	20'-3"	26'-8"	24'-8"	23'-6"	20'-3"
	NI-60	25'-10"	23'-11"	22'-10"	19'-8"	26'-8"	24'-9"	23'-4"	19'-8"
	NI-80	27'-9"	25'-7"	24'-5"	21'-11"	28'-6"	26'-5"	25'-2"	21'-11"
	NI-90	28'-3"	26'-1"	24'-10"	21'-11"	29'-0"	26'-10"	25'-7"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-0"	15'-7"	14'-2"	12'-8"	18'-0"	15'-7"	14'-2"	12'-8"
	NI-40x	19'-1"	16'-6"	15'-0"	13'-5"	19'-1"	16'-6"	15'-0"	13'-5"
	NI-60	20'-5"	18'-11"	17'-3"	14'-4"	20'-10"	18'-11"	17'-3"	14'-4"
	NI-80	21'-11"	20'-5"	18'-0"	14'-4"	22'-5"	20'-11"	18'-0"	14'-4"
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-9"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	23'-11"	21'-7"	19'-8"	17'-7"	24'-7"	21'-7"	19'-8"	17'-7"
	NI-80	25'-7"	23'-10"	22'-4"	17'-10"	26'-2"	24'-5"	22'-4"	17'-10"
14"	NI-90	26'-2"	24'-3"	23'-2"	20'-3"	26'-8"	24'-10"	23'-9"	20'-3"
	NI-40x	23'-11"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	26'-11"	23'-8"	21'-7"	18'-11"	27'-5"	23'-8"	21'-7"	18'-11"
	NI-80	28'-9"	26'-8"	25'-2"	20'-1"	29'-5"	27'-5"	25'-2"	20'-1"
16"	NI-90	29'-4"	27'-2"	25'-4"	20'-3"	29'-11"	27'-11"	25'-4"	20'-3"
	NI-60	29'-6"	25'-6"	23'-4"	19'-8"	29'-6"	25'-6"	23'-4"	19'-8"
	NI-80	31'-7"	29'-4"	27'-6"	21'-11"	32'-5"	30'-1"	27'-6"	21'-11"
	NI-90	32'-3"	29'-10"	27'-6"	21'-11"	33'-2"	30'-7"	27'-6"	21'-11"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H4.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-11"	15'-0"	14'-3"	12'-9"	16'-5"	15'-5"	14'-3"	12'-9"
	NI-40x	17'-0"	16'-0"	15'-1"	13'-6"	17'-5"	16'-5"	15'-1"	13'-6"
	NI-60	17'-2"	16'-2"	15'-7"	14'-11"	17'-7"	16'-7"	16'-0"	15'-4"
	NI-80	18'-3"	17'-1"	16'-5"	15'-9"	18'-8"	17'-5"	16'-9"	16'-1"
11-7/8"	NI-20	17'-11"	16'-11"	16'-3"	14'-6"	18'-7"	17'-5"	16'-3"	14'-6"
	NI-40x	19'-4"	17'-11"	17'-3"	15'-5"	19'-11"	18'-6"	17'-3"	15'-5"
	NI-60	19'-7"	18'-2"	17'-6"	16'-9"	20'-2"	18'-9"	17'-11"	17'-2"
	NI-80	21'-1"	19'-6"	18'-6"	17'-7"	21'-7"	20'-0"	19'-0"	18'-0"
	NI-90	21'-6"	19'-10"	18'-11"	17'-11"	22'-0"	20'-4"	19'-5"	18'-4"
14"	NI-40x	21'-5"	19'-11"	18'-11"	16'-11"	22'-1"	20'-7"	18'-11"	16'-11"
	NI-60	21'-10"	20'-2"	19'-3"	18'-3"	22'-6"	20'-10"	19'-11"	18'-10"
	NI-80	23'-5"	21'-7"	20'-7"	19'-5"	24'-0"	22'-3"	21'-2"	20'-0"
	NI-90	23'-10"	22'-1"	21'-0"	19'-10"	24'-5"	22'-7"	21'-6"	20'-4"
16"	NI-60	23'-9"	22'-0"	21'-0"	19'-10"	24'-6"	22'-9"	21'-8"	20'-7"
	NI-80	25'-6"	23'-7"	22'-5"	21'-2"	26'-2"	24'-3"	23'-1"	21'-10"
	NI-90	26'-0"	24'-0"	22'-10"	21'-6"	26'-7"	24'-8"	23'-5"	22'-2"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-3"	12'-9"	16'-10"	15'-5"	14'-3"	12'-9"
	NI-40x	18'-8"	16'-7"	15'-1"	13'-6"	18'-10"	16'-7"	15'-1"	13'-6"
	NI-60	18'-11"	17'-6"	16'-6"	15'-5"	19'-2"	17'-6"	16'-6"	15'-5"
	NI-80	20'-3"	18'-10"	17'-11"	16'-10"	20'-8"	19'-3"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	17'-10"	16'-3"	14'-6"	20'-1"	17'-10"	16'-3"	14'-6"
	NI-40x	21'-10"	18'-10"	17'-3"	15'-5"	21'-10"	18'-10"	17'-3"	15'-5"
	NI-60	22'-1"	20'-7"	19'-8"	17'-8"	22'-8"	20'-10"	19'-8"	17'-8"
	NI-80	23'-8"	22'-0"	20'-11"	19'-10"	24'-1"	22'-6"	21'-6"	20'-0"
	NI-90	24'-1"	22'-5"	21'-4"	20'-2"	24'-7"	22'-11"	21'-10"	20'-7"
14"	NI-40x	24'-0"	20'-9"	18'-11"	16'-11"	24'-0"	20'-9"	18'-11"	16'-11"
	NI-60	24'-10"	23'-2"	21'-8"	19'-5"	25'-6"	23'-8"	21'-8"	19'-5"
	NI-80	26'-6"	24'-8"	23'-6"	22'-0"	27'-1"	25'-3"	24'-1"	22'-0"
	NI-90	27'-0"	25'-1"	23'-11"	22'-0"	27'-6"	25'-8"	24'-6"	22'-0"
16"	NI-60	27'-3"	25'-5"	23'-4"	20'-11"	28'-0"	25'-7"	23'-4"	20'-11"
	NI-80	29'-1"	27'-1"	25'-9"	23'-6"	29'-8"	27'-9"	26'-5"	23'-6"
	NI-90	29'-7"	27'-6"	26'-2"	23'-6"	30'-2"	28'-2"	26'-10"	23'-6"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H4.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-2"	15'-7"	14'-2"	12'-8"	17'-8"	15'-7"	14'-2"	12'-8"
	NI-40x	18'-5"	16'-6"	15'-0"	13'-5"	19'-0"	16'-6"	15'-0"	13'-5"
	NI-60	18'-8"	17'-5"	16'-10"	14'-4"	19'-3"	17'-11"	17'-3"	14'-4"
	NI-80	20'-1"	18'-7"	17'-9"	14'-4"	20'-7"	19'-1"	18'-0"	14'-4"
11-7/8"	NI-20	19'-8"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-4"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	21'-8"	20'-1"	19'-1"	17'-7"	22'-3"	20'-9"	19'-8"	17'-7"
	NI-80	23'-3"	21'-6"	20'-5"	17'-10"	23'-10"	22'-1"	21'-1"	17'-10"
14"	NI-90	23'-9"	21'-11"	20'-10"	19'-9"	24'-4"	22'-6"	21'-5"	20'-3"
	NI-40x	23'-8"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	24'-1"	22'-3"	21'-3"	18'-11"	24'-10"	23'-1"	21'-7"	18'-11"
	NI-80	25'-10"	23'-10"	22'-9"	20'-1"	26'-6"	24'-7"	23'-5"	20'-1"
16"	NI-90	26'-4"	24'-4"	23'-2"	20'-3"	27'-0"	25'-0"	23'-10"	20'-3"
	NI-60	26'-3"	24'-3"	23'-2"	19'-8"	27'-1"	25'-2"	23'-4"	19'-8"
	NI-80	28'-2"	26'-0"	24'-9"	21'-11"	28'-10"	26'-9"	25'-6"	21'-11"
	NI-90	28'-8"	26'-6"	25'-2"	21'-11"	29'-5"	27'-3"	25'-11"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-0"	15'-7"	14'-2"	12'-8"	18'-0"	15'-7"	14'-2"	12'-8"
	NI-40x	19'-1"	16'-6"	15'-0"	13'-5"	19'-1"	16'-6"	15'-0"	13'-5"
	NI-60	20'-8"	18'-11"	17'-3"	14'-4"	20'-10"	18'-11"	17'-3"	14'-4"
	NI-80	22'-2"	20'-7"	18'-0"	14'-4"	22'-8"	20'-11"	18'-0"	14'-4"
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-9"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	24'-2"	21'-7"	19'-8"	17'-7"	24'-10"	21'-7"	19'-8"	17'-7"
	NI-80	25'-10"	24'-1"	22'-4"	17'-10"	26'-5"	24'-8"	22'-4"	17'-10"
14"	NI-90	26'-4"	24'-6"	23'-4"	20'-3"	26'-11"	25'-1"	23'-11"	20'-3"
	NI-40x	23'-11"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	27'-2"	23'-8"	21'-7"	18'-11"	27'-5"	23'-8"	21'-7"	18'-11"
	NI-80	29'-0"	27'-0"	25'-2"	20'-1"	29'-7"	27'-8"	25'-2"	20'-1"
16"	NI-90	29'-7"	27'-6"	25'-4"	20'-3"	30'-2"	28'-2"	25'-4"	20'-3"
	NI-60	29'-6"	25'-6"	23'-4"	19'-8"	29'-6"	25'-6"	23'-4"	19'-8"
	NI-80	31'-10"	29'-7"	27'-6"	21'-11"	32'-9"	30'-4"	27'-6"	21'-11"
	NI-90	32'-7"	30'-1"	27'-6"	21'-11"	33'-6"	30'-10"	27'-6"	21'-11"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H5.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-8"	15'-5"	14'-3"	12'-9"	17'-0"	15'-5"	14'-3"	12'-9"
	NI-40x	17'-9"	16'-7"	15'-1"	13'-6"	18'-2"	16'-7"	15'-1"	13'-6"
	NI-60	17'-11"	16'-11"	16'-3"	15'-6"	18'-5"	17'-3"	16'-8"	15'-6"
	NI-80	19'-3"	17'-10"	17'-2"	16'-5"	19'-8"	18'-3"	17'-6"	16'-9"
11-7/8"	NI-20	18'-11"	17'-8"	16'-3"	14'-6"	19'-7"	17'-10"	16'-3"	14'-6"
	NI-40x	20'-5"	18'-10"	17'-3"	15'-5"	21'-0"	18'-10"	17'-3"	15'-5"
	NI-60	20'-8"	19'-3"	18'-4"	17'-5"	21'-3"	19'-10"	18'-11"	17'-8"
	NI-80	22'-2"	20'-7"	19'-7"	18'-5"	22'-8"	21'-1"	20'-1"	18'-11"
14"	NI-90	22'-8"	21'-0"	19'-11"	18'-9"	23'-2"	21'-6"	20'-5"	19'-3"
	NI-40x	22'-7"	20'-9"	18'-11"	16'-11"	23'-3"	20'-9"	18'-11"	16'-11"
	NI-60	23'-0"	21'-4"	20'-4"	19'-2"	23'-8"	22'-0"	21'-0"	19'-5"
	NI-80	24'-8"	22'-10"	21'-8"	20'-5"	25'-3"	23'-5"	22'-4"	21'-0"
16"	NI-90	25'-2"	23'-3"	22'-1"	20'-10"	25'-8"	23'-10"	22'-8"	21'-5"
	NI-60	25'-1"	23'-3"	22'-1"	20'-10"	25'-9"	24'-0"	22'-11"	20'-11"
	NI-80	26'-10"	24'-10"	23'-7"	22'-3"	27'-6"	25'-6"	24'-3"	22'-11"
	NI-90	27'-4"	25'-4"	24'-1"	22'-7"	27'-11"	25'-11"	24'-8"	23'-3"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-0"	15'-5"	14'-3"	12'-9"	17'-0"	15'-5"	14'-3"	12'-9"
	NI-40x	19'-0"	16'-7"	15'-1"	13'-6"	19'-0"	16'-7"	15'-1"	13'-6"
	NI-60	19'-3"	17'-8"	16'-8"	15'-6"	19'-3"	17'-8"	16'-8"	15'-6"
	NI-80	20'-11"	19'-5"	18'-3"	17'-0"	21'-3"	19'-5"	18'-3"	17'-0"
11-7/8"	NI-20	20'-4"	17'-10"	16'-3"	14'-6"	20'-4"	17'-10"	16'-3"	14'-6"
	NI-40x	21'-10"	18'-10"	17'-3"	15'-5"	21'-10"	18'-10"	17'-3"	15'-5"
	NI-60	22'-10"	21'-0"	19'-9"	17'-8"	23'-0"	21'-0"	19'-9"	17'-8"
	NI-80	24'-5"	22'-9"	21'-8"	20'-2"	24'-11"	23'-0"	21'-8"	20'-2"
14"	NI-90	24'-11"	23'-3"	22'-2"	20'-9"	25'-4"	23'-8"	22'-3"	20'-9"
	NI-40x	24'-0"	20'-9"	18'-11"	16'-11"	24'-0"	20'-9"	18'-11"	16'-11"
	NI-60	25'-7"	23'-9"	21'-8"	19'-5"	26'-1"	23'-9"	21'-8"	19'-5"
	NI-80	27'-4"	25'-6"	24'-4"	22'-0"	27'-10"	26'-1"	24'-7"	22'-0"
16"	NI-90	27'-10"	26'-0"	24'-9"	22'-0"	28'-4"	26'-7"	25'-3"	22'-0"
	NI-60	28'-1"	25'-7"	23'-4"	20'-11"	28'-9"	25'-7"	23'-4"	20'-11"
	NI-80	29'-11"	27'-11"	26'-8"	23'-6"	30'-6"	28'-7"	27'-3"	23'-6"
	NI-90	30'-6"	28'-5"	27'-1"	23'-6"	31'-0"	29'-1"	27'-9"	23'-6"

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H5.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	7/8 in. nailed-glued oriented strand board (OSB) sheathing

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-11"	15'-7"	14'-2"	12'-8"	18'-0"	15'-7"	14'-2"	12'-8"
	NI-40x	19'-1"	16'-6"	15'-0"	13'-5"	19'-1"	16'-6"	15'-0"	13'-5"
	NI-60	19'-9"	18'-4"	17'-3"	14'-4"	20'-3"	18'-11"	17'-3"	14'-4"
	NI-80	21'-3"	19'-8"	18'-0"	14'-4"	21'-8"	20'-2"	18'-0"	14'-4"
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-9"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	22'-10"	21'-2"	19'-8"	17'-7"	23'-6"	21'-7"	19'-8"	17'-7"
	NI-80	24'-6"	22'-8"	21'-7"	17'-10"	25'-1"	23'-3"	22'-2"	17'-10"
14"	NI-90	25'-0"	23'-2"	22'-0"	20'-3"	25'-7"	23'-9"	22'-7"	20'-3"
	NI-40x	23'-11"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	25'-4"	23'-6"	21'-7"	18'-11"	26'-1"	23'-8"	21'-7"	18'-11"
	NI-80	27'-2"	25'-2"	24'-0"	20'-1"	27'-10"	25'-11"	24'-8"	20'-1"
16"	NI-90	27'-9"	25'-8"	24'-5"	20'-3"	28'-4"	26'-4"	25'-1"	20'-3"
	NI-60	27'-7"	25'-6"	23'-4"	19'-8"	28'-5"	25'-6"	23'-4"	19'-8"
	NI-80	29'-7"	27'-5"	26'-1"	21'-11"	30'-4"	28'-2"	26'-10"	21'-11"
	NI-90	30'-2"	27'-11"	26'-7"	21'-11"	30'-10"	28'-8"	27'-4"	21'-11"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-0"	15'-7"	14'-2"	12'-8"	18'-0"	15'-7"	14'-2"	12'-8"
	NI-40x	19'-1"	16'-6"	15'-0"	13'-5"	19'-1"	16'-6"	15'-0"	13'-5"
	NI-60	21'-0"	18'-11"	17'-3"	14'-4"	21'-0"	18'-11"	17'-3"	14'-4"
	NI-80	22'-11"	21'-1"	18'-0"	14'-4"	23'-1"	21'-1"	18'-0"	14'-4"
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-9"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	24'-11"	21'-7"	19'-8"	17'-7"	24'-11"	21'-7"	19'-8"	17'-7"
	NI-80	26'-9"	24'-11"	22'-4"	17'-10"	27'-3"	25'-1"	22'-4"	17'-10"
14"	NI-90	27'-3"	25'-5"	24'-3"	20'-3"	27'-10"	25'-9"	24'-3"	20'-3"
	NI-40x	23'-11"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	27'-5"	23'-8"	21'-7"	18'-11"	27'-5"	23'-8"	21'-7"	18'-11"
	NI-80	29'-11"	27'-11"	25'-2"	20'-1"	30'-6"	28'-3"	25'-2"	20'-1"
16"	NI-90	30'-6"	28'-5"	25'-4"	20'-3"	31'-1"	29'-1"	25'-4"	20'-3"
	NI-60	29'-6"	25'-6"	23'-4"	19'-8"	29'-6"	25'-6"	23'-4"	19'-8"
	NI-80	33'-1"	30'-5"	27'-6"	21'-11"	34'-0"	30'-5"	27'-6"	21'-11"
	NI-90	33'-11"	31'-2"	27'-6"	21'-11"	34'-10"	31'-11"	27'-6"	21'-11"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H6.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	14'-11"	14'-1"	13'-7"	-	15'-4"	14'-6"	14'-1"	-
	NI-40x	15'-11"	15'-0"	14'-6"	-	16'-4"	15'-5"	14'-11"	-
	NI-60	16'-1"	15'-2"	14'-8"	-	16'-6"	15'-7"	15'-1"	-
	NI-80	17'-1"	16'-1"	15'-6"	-	17'-5"	16'-5"	15'-10"	-
11-7/8"	NI-20	16'-9"	15'-10"	15'-4"	-	17'-4"	16'-4"	15'-10"	-
	NI-40x	17'-10"	16'-10"	16'-3"	-	18'-6"	17'-4"	16'-9"	-
	NI-60	18'-1"	17'-0"	16'-5"	-	18'-9"	17'-6"	16'-11"	-
	NI-80	19'-6"	18'-0"	17'-4"	-	20'-1"	18'-7"	17'-9"	-
	NI-90	19'-11"	18'-4"	17'-8"	-	20'-5"	18'-11"	18'-1"	-
14"	NI-40x	19'-10"	18'-4"	17'-8"	-	20'-6"	19'-1"	18'-3"	-
	NI-60	20'-2"	18'-8"	17'-11"	-	20'-10"	19'-4"	18'-6"	-
	NI-80	21'-8"	20'-0"	19'-1"	-	22'-4"	20'-8"	19'-9"	-
	NI-90	22'-1"	20'-5"	19'-6"	-	22'-9"	21'-0"	20'-1"	-
16"	NI-60	22'-0"	20'-4"	19'-6"	-	22'-9"	21'-1"	20'-2"	-
	NI-80	23'-7"	21'-10"	20'-10"	-	24'-4"	22'-6"	21'-6"	-
	NI-90	24'-1"	22'-2"	21'-2"	-	24'-9"	22'-11"	21'-10"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-6"	15'-1"	14'-3"	-	16'-6"	15'-1"	14'-3"	-
	NI-40x	17'-9"	16'-7"	15'-1"	-	18'-2"	16'-7"	15'-1"	-
	NI-60	17'-11"	16'-11"	16'-2"	-	18'-5"	17'-2"	16'-2"	-
	NI-80	19'-3"	17'-10"	17'-3"	-	19'-8"	18'-3"	17'-7"	-
11-7/8"	NI-20	19'-4"	17'-10"	16'-3"	-	19'-9"	17'-10"	16'-3"	-
	NI-40x	20'-10"	18'-10"	17'-3"	-	21'-5"	18'-10"	17'-3"	-
	NI-60	21'-1"	19'-7"	18'-8"	-	21'-8"	20'-2"	19'-3"	-
	NI-80	22'-6"	20'-10"	19'-11"	-	23'-1"	21'-5"	20'-5"	-
	NI-90	23'-0"	21'-3"	20'-4"	-	23'-6"	21'-10"	20'-10"	-
14"	NI-40x	23'-5"	20'-9"	18'-11"	-	24'-0"	20'-9"	18'-11"	-
	NI-60	23'-9"	22'-0"	21'-0"	-	24'-5"	22'-8"	21'-8"	-
	NI-80	25'-4"	23'-6"	22'-5"	-	25'-11"	24'-1"	23'-0"	-
	NI-90	25'-10"	23'-11"	22'-9"	-	26'-5"	24'-6"	23'-4"	-
16"	NI-60	26'-2"	24'-3"	23'-2"	-	26'-11"	25'-0"	23'-4"	-
	NI-80	27'-11"	25'-10"	24'-7"	-	28'-7"	26'-6"	25'-3"	-
	NI-90	28'-5"	26'-3"	25'-0"	-	29'-0"	26'-11"	25'-8"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H6.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	5/8 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-0"	15'-2"	14'-2"	-	16'-7"	15'-7"	14'-2"	-
	NI-40x	17'-2"	16'-2"	15'-0"	-	17'-8"	16'-6"	15'-0"	-
	NI-60	17'-4"	16'-4"	15'-10"	-	17'-10"	16'-10"	16'-3"	-
	NI-80	18'-7"	17'-4"	16'-9"	-	19'-2"	17'-9"	17'-2"	-
11-7/8"	NI-20	18'-1"	17'-1"	16'-2"	-	18'-11"	17'-8"	16'-2"	-
	NI-40x	19'-8"	18'-3"	17'-2"	-	20'-5"	18'-10"	17'-2"	-
	NI-60	20'-0"	18'-6"	17'-9"	-	20'-8"	19'-2"	18'-5"	-
	NI-80	21'-6"	19'-11"	19'-0"	-	22'-2"	20'-6"	19'-7"	-
	NI-90	22'-0"	20'-4"	19'-5"	-	22'-7"	20'-11"	20'-0"	-
14"	NI-40x	21'-10"	20'-3"	18'-10"	-	22'-8"	20'-8"	18'-10"	-
	NI-60	22'-3"	20'-7"	19'-9"	-	23'-0"	21'-5"	20'-6"	-
	NI-80	23'-11"	22'-1"	21'-1"	-	24'-8"	22'-10"	21'-10"	-
	NI-90	24'-5"	22'-7"	21'-6"	-	25'-2"	23'-3"	22'-3"	-
16"	NI-60	24'-3"	22'-6"	21'-6"	-	25'-2"	23'-4"	22'-4"	-
	NI-80	26'-1"	24'-1"	23'-0"	-	26'-11"	24'-11"	23'-9"	-
	NI-90	26'-7"	24'-7"	23'-5"	-	27'-5"	25'-4"	24'-2"	-

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-10"	15'-7"	14'-2"	-	17'-11"	15'-7"	14'-2"	-
	NI-40x	19'-1"	16'-6"	15'-0"	-	19'-1"	16'-6"	15'-0"	-
	NI-60	19'-7"	18'-2"	17'-3"	-	20'-2"	18'-8"	17'-3"	-
	NI-80	21'-0"	19'-6"	18'-0"	-	21'-6"	20'-0"	18'-0"	-
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	-	20'-6"	17'-9"	16'-2"	-
	NI-40x	21'-9"	18'-10"	17'-2"	-	21'-9"	18'-10"	17'-2"	-
	NI-60	23'-0"	21'-4"	19'-8"	-	23'-8"	21'-7"	19'-8"	-
	NI-80	24'-8"	22'-10"	21'-9"	-	25'-3"	23'-5"	22'-4"	-
	NI-90	25'-2"	23'-3"	22'-3"	-	25'-9"	23'-11"	22'-10"	-
14"	NI-40x	23'-11"	20'-8"	18'-10"	-	23'-11"	20'-8"	18'-10"	-
	NI-60	25'-11"	23'-8"	21'-7"	-	26'-8"	23'-8"	21'-7"	-
	NI-80	27'-8"	25'-8"	24'-6"	-	28'-4"	26'-4"	25'-2"	-
	NI-90	28'-3"	26'-2"	24'-11"	-	28'-11"	26'-10"	25'-4"	-
16"	NI-60	28'-7"	25'-6"	23'-4"	-	29'-4"	25'-6"	23'-4"	-
	NI-80	30'-6"	28'-3"	26'-11"	-	31'-2"	29'-0"	27'-6"	-
	NI-90	31'-1"	28'-9"	27'-4"	-	31'-9"	29'-6"	27'-6"	-

Notes:

- The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
- For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
- Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
- Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
- Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H7.1

Design Criteria

Spans:	Simple span
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare				1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	15'-10"	15'-0"	14'-3"	12'-9"	16'-4"	15'-5"	14'-3"	12'-9"
	NI-40x	16'-11"	15'-11"	15'-1"	13'-6"	17'-4"	16'-4"	15'-1"	13'-6"
	NI-60	17'-1"	16'-1"	15'-6"	14'-10"	17'-6"	16'-6"	15'-11"	15'-3"
	NI-80	18'-1"	17'-0"	16'-4"	15'-8"	18'-7"	17'-4"	16'-8"	16'-0"
11-7/8"	NI-20	17'-10"	16'-10"	16'-2"	14'-6"	18'-5"	17'-4"	16'-3"	14'-6"
	NI-40x	19'-3"	17'-10"	17'-2"	15'-5"	19'-10"	18'-5"	17'-3"	15'-5"
	NI-60	19'-6"	18'-1"	17'-4"	16'-8"	20'-1"	18'-8"	17'-10"	17'-1"
	NI-80	20'-11"	19'-4"	18'-5"	17'-7"	21'-5"	19'-10"	18'-11"	17'-11"
	NI-90	21'-4"	19'-9"	18'-9"	17'-10"	21'-10"	20'-3"	19'-3"	18'-3"
14"	NI-40x	21'-4"	19'-9"	18'-10"	16'-11"	22'-0"	20'-5"	18'-11"	16'-11"
	NI-60	21'-8"	20'-1"	19'-2"	18'-2"	22'-4"	20'-9"	19'-9"	18'-9"
	NI-80	23'-3"	21'-6"	20'-5"	19'-4"	23'-10"	22'-1"	21'-0"	19'-11"
	NI-90	23'-9"	21'-11"	20'-10"	19'-8"	24'-3"	22'-6"	21'-5"	20'-3"
16"	NI-60	23'-7"	21'-10"	20'-10"	19'-9"	24'-4"	22'-7"	21'-7"	20'-5"
	NI-80	25'-4"	23'-5"	22'-3"	21'-1"	26'-0"	24'-1"	22'-11"	21'-8"
	NI-90	25'-10"	23'-10"	22'-8"	21'-5"	26'-5"	24'-6"	23'-4"	22'-0"

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap				Mid-span blocking and 1/2 in. gypsum ceiling			
		On centre spacing				On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	16'-10"	15'-5"	14'-3"	12'-9"	16'-10"	15'-5"	14'-3"	12'-9"
	NI-40x	18'-7"	16'-7"	15'-1"	13'-6"	18'-10"	16'-7"	15'-1"	13'-6"
	NI-60	18'-10"	17'-6"	16'-6"	15'-5"	19'-1"	17'-6"	16'-6"	15'-5"
	NI-80	20'-2"	18'-9"	17'-11"	16'-10"	20'-7"	19'-2"	18'-2"	16'-10"
11-7/8"	NI-20	20'-1"	17'-10"	16'-3"	14'-6"	20'-1"	17'-10"	16'-3"	14'-6"
	NI-40x	21'-9"	18'-10"	17'-3"	15'-5"	21'-10"	18'-10"	17'-3"	15'-5"
	NI-60	22'-0"	20'-6"	19'-7"	17'-8"	22'-7"	20'-10"	19'-8"	17'-8"
	NI-80	23'-6"	21'-10"	20'-10"	19'-9"	24'-0"	22'-5"	21'-4"	20'-0"
	NI-90	24'-0"	22'-4"	21'-3"	20'-1"	24'-6"	22'-10"	21'-9"	20'-7"
14"	NI-40x	24'-0"	20'-9"	18'-11"	16'-11"	24'-0"	20'-9"	18'-11"	16'-11"
	NI-60	24'-9"	23'-0"	21'-8"	19'-5"	25'-5"	23'-8"	21'-8"	19'-5"
	NI-80	26'-5"	24'-6"	23'-4"	22'-0"	27'-0"	25'-2"	24'-0"	22'-0"
	NI-90	26'-11"	25'-0"	23'-10"	22'-0"	27'-5"	25'-7"	24'-5"	22'-0"
16"	NI-60	27'-2"	25'-4"	23'-4"	20'-11"	27'-11"	25'-7"	23'-4"	20'-11"
	NI-80	29'-0"	26'-11"	25'-8"	23'-6"	29'-7"	27'-7"	26'-4"	23'-6"
	NI-90	29'-6"	27'-5"	26'-1"	23'-6"	30'-1"	28'-1"	26'-9"	23'-6"

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.

Maximum Floor Spans – H7.2

Design Criteria

Spans:	Multiple spans
Loads:	Live load = 40 psf and dead load = 35 psf
Deflection limits:	L/480 under live load and L/240 under total load
Sheathing:	3/4 in. nailed-glued Canadian softwood plywood

Maximum Floor Spans

Joist depth	Joist series	Bare On centre spacing				1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	17'-1"	15'-7"	14'-2"	12'-8"	17'-7"	15'-7"	14'-2"	12'-8"
	NI-40x	18'-4"	16'-6"	15'-0"	13'-5"	18'-11"	16'-6"	15'-0"	13'-5"
	NI-60	18'-7"	17'-4"	16'-9"	14'-4"	19'-1"	17'-9"	17'-2"	14'-4"
	NI-80	20'-0"	18'-6"	17'-8"	14'-4"	20'-6"	19'-0"	18'-0"	14'-4"
11-7/8"	NI-20	19'-7"	17'-9"	16'-2"	14'-5"	20'-4"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-2"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	21'-6"	19'-11"	19'-0"	17'-7"	22'-2"	20'-7"	19'-8"	17'-7"
	NI-80	23'-1"	21'-4"	20'-4"	17'-10"	23'-8"	21'-11"	20'-11"	17'-10"
14"	NI-90	23'-7"	21'-9"	20'-9"	19'-8"	24'-2"	22'-5"	21'-4"	20'-2"
	NI-40x	23'-6"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	23'-11"	22'-2"	21'-1"	18'-11"	24'-8"	22'-11"	21'-7"	18'-11"
	NI-80	25'-8"	23'-9"	22'-7"	20'-1"	26'-4"	24'-5"	23'-3"	20'-1"
16"	NI-90	26'-2"	24'-2"	23'-0"	20'-3"	26'-10"	24'-10"	23'-8"	20'-3"
	NI-60	26'-1"	24'-1"	23'-0"	19'-8"	26'-11"	25'-0"	23'-4"	19'-8"
	NI-80	27'-11"	25'-10"	24'-7"	21'-11"	28'-8"	26'-7"	25'-4"	21'-11"
NI-90	28'-6"	26'-4"	25'-0"	21'-11"	29'-3"	27'-1"	25'-9"	21'-11"	

Joist depth	Joist series	Mid-span blocking with 1x4 inch strap On centre spacing				Mid-span blocking and 1/2 in. gypsum ceiling On centre spacing			
		12"	16"	19.2"	24"	12"	16"	19.2"	24"
9-1/2"	NI-20	18'-0"	15'-7"	14'-2"	12'-8"	18'-0"	15'-7"	14'-2"	12'-8"
	NI-40x	19'-1"	16'-6"	15'-0"	13'-5"	19'-1"	16'-6"	15'-0"	13'-5"
	NI-60	20'-7"	18'-11"	17'-3"	14'-4"	20'-10"	18'-11"	17'-3"	14'-4"
	NI-80	22'-1"	20'-6"	18'-0"	14'-4"	22'-7"	20'-11"	18'-0"	14'-4"
11-7/8"	NI-20	20'-6"	17'-9"	16'-2"	14'-5"	20'-6"	17'-9"	16'-2"	14'-5"
	NI-40x	21'-9"	18'-10"	17'-2"	15'-4"	21'-9"	18'-10"	17'-2"	15'-4"
	NI-60	24'-1"	21'-7"	19'-8"	17'-7"	24'-9"	21'-7"	19'-8"	17'-7"
	NI-80	25'-9"	23'-11"	22'-4"	17'-10"	26'-4"	24'-7"	22'-4"	17'-10"
14"	NI-90	26'-3"	24'-5"	23'-3"	20'-3"	26'-10"	25'-0"	23'-10"	20'-3"
	NI-40x	23'-11"	20'-8"	18'-10"	16'-10"	23'-11"	20'-8"	18'-10"	16'-10"
	NI-60	27'-0"	23'-8"	21'-7"	18'-11"	27'-5"	23'-8"	21'-7"	18'-11"
	NI-80	28'-11"	26'-10"	25'-2"	20'-1"	29'-6"	27'-7"	25'-2"	20'-1"
16"	NI-90	29'-5"	27'-4"	25'-4"	20'-3"	30'-1"	28'-0"	25'-4"	20'-3"
	NI-60	29'-6"	25'-6"	23'-4"	19'-8"	29'-6"	25'-6"	23'-4"	19'-8"
	NI-80	31'-8"	29'-6"	27'-6"	21'-11"	32'-7"	30'-3"	27'-6"	21'-11"
NI-90	32'-5"	30'-0"	27'-6"	21'-11"	33'-4"	30'-9"	27'-6"	21'-11"	

Notes:

1. The tabulated clear spans are based on CSA O86-14 and NBC 2015, and are applicable to residential floor construction meeting the above design criteria.
2. For multiple-span applications, the end spans shall be 40% or more of the adjacent span.
3. Minimum bearing length shall be 1-3/4 inch for end bearings, and 3-1/2 inches for intermediate bearings.
4. Bearing stiffeners are not required when I-joists are used in accordance with this table, except as required for hangers.
5. Nordic I-joists are listed in CCMC Evaluation Report 13032-R and APA Product Report PR-L274C.